

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2021/WZ/Cos/ **318**

Dated: **13/07/2021**

**FIRE SAFETY CERTIFICATE**

Certified that the M/s **Himanshu Cosmetics**, located at **H-234, Sec-3, Bawana, Industrial Area, Bawana Delhi-110039** comprised of **Basement+Ground+Two upper floors** owned/occupied by M/s **Himanshu Cosmetics** was issued fire safety certificate vide **Letter No. F6/DFS/MS/2018/WZ/501 dated 26/03/2018** have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on **17/06/2021** in the presence of **Sh. Rajeev Sahni** and that the building premise is fit for occupancy under **"Class Industrial Building G-2(ii)"** with effect from **13/07/2021** for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **13/07/2021** at New Delhi

  
(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
WEST ZONE

**SR**

**Conditions for the validity of Fire Safety Certificate:**

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Copy to :-

1. M/s Himanshu Cosmetics, H-234, Sector-3, Bawana Industrial Area, Delhi-39.
2. Dy. Drug controller /licensing authority Govt. of NCT. Of Delhi, Drug Controller Department, F-17, Karkardooma, Delhi-110032.

**INSPECTION REPORT**

1. Name & address of the building: M/s Himanshu Cosmetics ,H-234, Sector-3 , DSIIDC  
Bawana Industrial Area, Delhi-39
2. Type of Occupancy : Industrial G-2(ii)
3. Building Comprised : **B+Gr.+2 upper floors**
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/2018/WZ/501 Dated-26/03/2018
6. Fire Safety directives letter No : DFS Act 2007 & Rule 2010/NBC Part IV
7. Date of inspection : 17.06.2021
8. Name of the Inspecting Officers : ADO (BW)
9. Name and designation of officers  
from the building side : Sh. Rajeev Sahni
9. Year of Construction : 2010-11
10. Applicant's letter No. : E Mail ID Dated-14/06/2021

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 m	Directly Accessible	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.50m	1.25 m & 0.96 m	MR(old case)
	• Basements	1.50m	1.25 m & 0.96 m	MR(old case)
	c. Protection of exits			
	• Fire check door	NA	NA	MR
	• Pressurization	NA	NA	MR
	d. No. of continuous staircases to terrace	01	Provided	MR

2

	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30a/c per hour	Exhaust Fan Provided	MR
	• Upper floors	12a/c per hour	Exhaust Fan Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	12 nos	20 nos	MR
	• Types	ABC	ABC	MR
	• IS marking	Required	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR

Q

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	➤ Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	20,000ltrs	MR

*a*

15	Exit Signage.	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standard on fire prevention and fire safety required under the rules, the FSC issued vide letter no. F6/DFS/MS/2018/WZ/501 dated 26/03/2018 is recommended for renewal of Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010

Signature of the Inspecting Officer  
Name: - Rajeev Kumar Sinha  
Designation-ADO/BW

*(Signature)*  
ADO(BW)  
21/6/21

*(Signature)*  
DO (NW)

*(Signature)*  
24/06/2021  
De ADO (W2)

*(Signature)*  
A.T letter  
ADO(BW)  
6/7/21  
5/7/2021  
Put up the sign plans  
7/7/2021