

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/School/2021/SZ/ 498

Dated: 16/7/2021

FIRE SAFETY CERTIFICATE

Certified that **S.D.M.C Model Primary Co-ed School, at Zamrudpur New Delhi -110048** Comprised of ground plus One upper floors owned / Occupied by SDMC was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/1294 Dt. 04/06/2018. The said premises was re-inspected by officer concerned of this department on 07/07/2021 in presence of Smt. Uma Rani of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 16/7/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 16/7/2021 at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Principal, S.D.M.C Model Primary Co-ed School, at Zamrudpur New Delhi -110048.
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

M/S

INSPECTION REPORT

1	Name & Address of the Building	S.D.M.C Model Primary Co-ed School, at Zamrudpur New Delhi -110048.		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus One upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/1294 Dt. 04/06/2018		
6	Fire Safety Directives Letter No	DOE Circular 01/03/2011		
7	Date of Inspection	07-07-2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Smt. Uma Rani		
10	Year of construction	2010		
11	Applicant letter No.	Gmail ID Dated 10/06/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC/UBBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	Provided	MR
	• Gate width	-NA-	4.5 mtr	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 No's	02 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5 / 0.75 m	1.50 m each	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	1.50 mtr	-NA-
	f) Door size	1.0 m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	05 No's	Provided	MR
	• Types	ABC / Co2	ABC Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-
7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-

36 37 38 39

सेक्टर-1, नौएडा-013

N/15

	<ul style="list-style-type: none"> • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/1294 Dt. 04/06/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten signature]
8/7/2021

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD) - on leave

[Handwritten signature] P.T. please

~~ADO (BCP)~~

As approved, P.T. letter is put up for your signature pl

[Handwritten signature]
14/7

[Handwritten signature]

M.S. all