

C-14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 499

Dated: 16/7/2021

**FIRE SAFETY CERTIFICATE**

Certified that **S.D.M.C Primary Co-ed School, Kilokri Tank Jal Vihar, Lajpat Nagar Delhi -110024** Comprised of ground plus One upper floor owned / Occupied by SDMC was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2018/SZ/1891 Dt. 13/08/2018. The said premises was re-inspected by officer concerned of this department on 07/07/2021 in presence of Sh. R. C Dikshit (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 16/7/2021 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 16/7/2021 at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. The Principal, S.D.M.C Primary Co-ed School, Kilokri Tank Jal Vihar, Lajpat Nagar Delhi - 110024.
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

### INSPECTION REPORT

1	Name & Address of the Building	S.D.M.C Primary Co-ed School, Kilokri Tank Jal Vihar, Lajpat Nagar Delhi -110024.		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2018/SZ/1891 Dt. 13/08/2018		
6	Fire Safety Directives Letter No	DOE Circular 01/03/2011		
7	Date of Inspection	07-07-2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar, ADO (BCP)		
9	Name & Designation of Officers from the building side	Sh. R. C Dikshit (Principal)		
10	Year of construction	1967		
11	Applicant letter No.	Gmail ID Dated 30/06/2021		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>NBC/UBBL Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	5 mtr	5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	-NA-	-NA-	-NA-
	<b>e) Width of corridor</b>	1.50 m	1.50 mtr	MR
	<b>f) Door size</b>	1.0 m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	02 No's	Provided	MR
	• Types	ABC / Co2	ABC Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-



N/11

	<ul style="list-style-type: none"> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2018/SZ/1891 Dt. 13/08/2018, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

DO (SD) — on leave  
24/08/21

~~ADO/BIP~~

As approved, F.T. letter is put up for your signature pl.

10/4  
14/7

24/08/21   
M.S.