

C-26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2021/ School/WZ/ 481

Dated: 14/7/21

**FIRE SAFETY CERTIFICATE**

Certified that **White Leaf Public School** located at , **Gali No. 2-3, Plot No. 89, Pooth Khurd, Delhi-110039** comprised of **Ground+one upper floor** owned/occupied by **White Leaf Public School** was issued fire safety certificate **vide letter no. F-6/DFS/MS/2017/School/WZ/1079 Dated-24/07/2017**. The premises was inspected by the officer concerned of this department on 22.06.2021 in the presence of Sh. Sunil Sharma (Principal) and observed that the management has added two more floors and now building is comprised of **Basement+Ground+Three upper floors**. All the fire prevention & fire safety arrangement provided in the building was found as per Rules and in good working condition. The premises have therefore complied with the requirements under rule 33 of Delhi Fire Service Rules, 2010 and the building / premises is fit for occupancy of **Group B (Educational)** with effect from 14/7/21 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....14/7/21..... at New Delhi

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal , White Leaf Public School, Gali No. 2-3, Plot No. 89, Pooth Khurd, Delhi-110039.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : White Leaf Public School, Gali No.2-3, Plot No.-89, Pooth Khurd  
Delhi-110039
2. Type of Occupancy : Educational
3. Building Comprised : Previous- (B+Gr. + One upper floor) ,Now-(B+Gr.+Three upper floors)
4. Type of Case : New (Addition of floors )
5. Details of Previous NOC : Letter No. F.6/DFS/MS/2017/School/WZ/1079 Dated-24/07/2017
6. Fire Safety directives letter No : Director of Education Circular No.2011/3298-3398 &NBC Part-IV
7. Date of inspection : 22/06/2021
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers  
From the building side : Sh. Sunil Sharma (Principal)
10. Year of Construction : 2006 & 2020
11. Applicant's letter No. : E Mail id , Dated-26/03/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu./NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	6.0 m	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	02	02	MR
	• Basements	02	03	MR
	b. Width of staircases	NA	NA	NA
	• Upper Floor	1.50 m	1.50×2	MR
	• Basements	1.50 m	1.50×2 & 1.35 to 1.45 m	MR
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	01	02	MR
	f. Door Size	1 m	Provided	MR
		<del>1.00 m</del> 1.2m	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

*RS*

4.	<b>Smoke Management System</b>			
	• Basements	30 a/c per hour	Exhaust Fan Provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	15	20	MR
	• Types	ABC	ABC	MR
	• IS marking	Yes	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>			
9.	<b>Public Address System</b>			
		Required	Provided	MR
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	MR
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	NA	NA
	• Number of hydrants per floor	01	NA	NA
	• Hose Box	01	NA	NA
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA

*Dr*

	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Terrace level</li> </ul>	-	-	-
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	900 lpm	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	40 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	-	-	-
		NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	15,000 ltrs Required	25,000 ltrs Provided	MR MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	NA	NA	NA
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Battery backup</li> </ul>	NA	NA	NA

*Dr*

	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The Fire Safety Certificate was issued for a building comprised of B+Gr.+One upper floor, now management has added two more floors in existing building and now the building is comprised of B+Gr+Three upper floors. The fire protection systems provided in the building were as per Rules & tested, checked and found functional at the time of inspection.

Keeping in view of the compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended for Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

DO (PW)  
*[Signature]*  
 29/06/2021

*[Signature]*  
 ADO (B.W.)  
 25/6/21

Signature of Inspecting Officer

Name : Rajeev Kumar Sinha

Designation : ADO/B.W.



Dy cfo (W2)

Check done uddhu

ADDO B.W.

spoken necessary corrections in inspection performed  
*[Signature]*  
 ADO (B.W.)  
 6/7/21

ADDO (W2)

*[Signature]*  
 7/7/2021

cfo

*[Signature]*

FT PLS

ADDO B.W.

...vered please...  
 ...सी सी (इंडिया)