

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No.F6/DFS/MS/GH/SZ/2021/ 228

Dated: 19/7/21

**FIRE SAFETY CERTIFICATE**

Certified that **M/s. Cosmo Guest house located at 7A/40, WEA, Channa Market, Karol Bagh, New Delhi- 110005** comprised of basement (hall), ground floor (reception, office, store & 01 guest room), first floor (07 guest room), second floor (07 guest rooms) and third floor (01 room for staff with pantry) (total 15 guest rooms), was granted FSC by this department vide letter No. F6/DFS/MS/GH/SZ/2017/1002 dated 11.07.2017. The premises was re-inspected by the officer concerned of this department on 15.07.2021 in presence of Mr. Raju Arora, Supervisor of the guest house and found that the guest house is deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) **for basement (Storage), ground floor (reception, office, store & 01 guest room), first & second floor each having 07 guest rooms) third floor (01 room for staff) (total 15 guest rooms only)** with effect from 19/7/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed back side.

Issued 19/7/21 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
01/c Delhi Fire Service

Copy to :-

1. The Manager, M/s. Cosmo Guest house, 7A/40, WEA, Channa Market, Karol Bagh, New Delhi- 110005.
2. The Joint C.P.(Lic.), Police Station, Defence Colony, 1<sup>st</sup> floor, New Delhi

Following Fire Safety Directives must be adhered to: -

1. **The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/359-374 dated 29.06.2021 in respect of existing building (copy enclosed) shall be implemented by 30.09.2021 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void**
2. No occupancy above third floor & basement as storage purpose, shall be adhered by Owner/Occupier
3. All the means of escape shall be kept free of all type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
7. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
8. All comments / directions of licensing department shall always be permitted and followed.
9. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
10. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
11. Basement shall be used as per BBL.
12. No temporary shed is allowed on terrace.
13. The Fire Safety Certificate is only for Guest Rooms.



1. Name & address of the building : M/s. Cosmo Guest house, 7A/40, WEA, Channa Market, Karol Bagh, New Delhi- 110005
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/SZ/2017/1002 dated 11.07.2017
5. Fire Safety directives letter No : N/A
6. Date of inspection : 15.07.2021
7. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
8. Name and designation of officers from the building side : Mr. Raju Arora, Supervisor
9. Year of Construction : Before 2000
10. Applicant's letter No. : Online Application id 2021061313810 dated 15.06.2021

The said guest house is comprised of basement (Storage), ground floor (reception, office, store & 01 guest room), first floor (07 guest room), second floor (07 guest rooms) and third floor (01 room for staff) (total 15 guest rooms)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Existing fire safety requirements as per FSC dated 11.07.2017	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR being old case
	• Basements	01	01	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	1.0 mts	1.22 mts	MR being old case
	• Basements	1.0 mts	1.30 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	Required	Not Provided	date of compliance has been extended up to 30.09.2021
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	1.0 mts	1.28 mts	MR
	h. Door Size	Old case	0.89 mts	MR being old case
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Not Provided	date of compliance has been extended up to 30.09.2021
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	12 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Exhaust fan provided	MR
5	<b>Fire Extinguishers</b>			







15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided (125 KVA)	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

All the shortcomings pointed out by this department vide letter No. F.6/DFS/MS/GH/SZ/2021/322 dated 12.04.2021 have been complied with by the guest house management.

The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/359-374 dated 29.06.2021 in respect of existing building (copy enclosed) shall be implemented by 30.09 .2021 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/GH/SZ/2017/1002 dated 11.07.2017, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

*[Signature]* 16/7/21

Signature of the Inspecting Officer  
P.V. Rathee  
Asstt. Div. Officer (SRD)

*[Signature]* D.O/SW)

*[Signature]* 16/07/2021

*[Signature]* Dy c/o (52)