

C-25

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2021/SZ/ 515

Dated: 20/7 /2021


FIRE SAFETY CERTIFICATE

Certified that the S.S. Khalsa Senior Secondary School (ID-1925195) located at Lajpat Nagar-IV, New Delhi-24, comprised of Ground & One Upper Floor owned / Occupied by S.S. Khalsa Senior Secondary School, have been issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2018/SZ/1371 dated 13/06/2018. The premises was re-inspected by the officer concerned of this department on 12.07.2021 in the presence of Sh. Sudhakar Bhardwaj (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 20/7 /2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 20/7 /2021 at New Delhi by


(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

- 
1. The Principal, S.S. Khalsa Senior Secondary School (ID-1925195), Lajpat Nagar-IV, New Delhi-24.
 2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	S.S. Khalsa Senior Secondary School (ID-1925195), Lajpat Nagar-IV, New Delhi-24.		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	Ground & 1 st Floor		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/School/2018/SZ/1371 dated 13/06/2018		
6.	Fire Safety directives Letter No	DOE Cir. Dated 01/03/2011		
7.	Date of Inspection	12.07.2021		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and Designation of Officer from the building side	Sh. Sudhakar Bhardwaj (Principal)		
10.	Year of Construction	2009-10		
11.	Applicant's letter No.	SSK/2021-22/98 dated 18/06/2021		
S. No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	6m	MR
	• Gate width	NA	4.5m	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	4	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 m or less & 0.75m	1.46m, 1.44m, 1.36m & 1.33m	MR (Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	1	MR
	e. Width Of Corridor	NA	1.5m	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	8	Provided	MR
	• Types	ABC / CO ₂	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA

113

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage			
		Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply			
		NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location			

24/17

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	DCP type fire extinguishers provided near electrical panel	MR

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2018/SZ/1371 dated 13/06/2018, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Ashok Jaiswal
12/07/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation: ADO (SJ)

DO (SD)

[Signature]
13/07

DeFO (SZ)

F. T. plan

A N O S J

F.T. is added for sign. please.

[Signature]
15/07/2021

Dy. C.F.O. (SZ)

[Signature]

MS. cell