

C-20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**


No. F.6/DFS/MS/School/2021/NDZ/ 532

Dated: 26/7/21

FIRE SAFETY CERTIFICATE

Certified that the Crescent School at Jamaloo ka Bagh, Road No. 66, Maujpur, Delhi-110053 comprised of basement, ground plus three upper floors (third floor of the building is sealed by M.C.D as per affidavit dated 25/11/2020) owned/occupied by Crescent School was issued FSC vide letter No.F.6/DFS/MS/School/2011/3715 dated 27/12/2011. The school building have complied with the fire prevention and fire safety requirements in accordance with circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officer concerned of Fire Service on dated 15/06/2021 in the presence of Ms. Zatoon Nisah, Principal of the school and that the school building is fit for occupancy class "B" 'Educational Building' for basement, ground plus two upper floors with effect from 26/7/21... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on 26/7/21.....at New Delhi by


(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,
The Principal,
Crescent School,
Jamaloo ka Bagh, Road No. 66,
Maujpur, Delhi-110053

Copy :-
The Joint Director of Education (Land & Estate),
Directorate of Education,
Lucknow Road, Delhi-110054.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. Basement shall not be used for any other purpose except as specified in UBBL/National Building Code.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

10. Name & address of the building : Crescent School, Main Road Maujpur, Opp. Metro Pillar No. 200, Delhi-110053
11. Building is comprised of : Basement, Ground plus three upper floors (Third floor has been sealed by MCD, School is running upto two floor only)
12. Type of Occupancy : Educational
13. Type of Case : Renewal
14. Details of Previous NOC letter : F6/DFS/MS/School/2011/3715 dt-27/12/2011
15. Fire Safety direction letter No : F16/Estate/CC/Fire Safety/2011/3298 to3398
Dated-01/03/11 issued by Director of Education
16. Date of Inspection : 15/06/2021
17. Name of the Inspecting officers : ADO Nagender Singh
18. Name and designation of Officer from the building side : Ms. Zatoon Nisah, Principal
10. Year of Construction : 1995
11. Applicant's Email ID : crescentschoolmaujpur@gmail.com
Dated-01/02/2021


Sr. No	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06m N/A N/A	20m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 nos. 02 nos.	03 nos. 03 nos.	MR MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.50m. 1.50m.	1.68m,1.40m & 1.12m 1.68m,1.40m & 1.12m	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	01 no.	02 nos.	MR
	e. Width of Corridor	1.50m.	1.80 m. & 1.5 m	MR
	f. Door Size	01 m.	01 m.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	Required Required	Provided Provided	MR MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	16 nos. ABC /CO ₂ ISI marked	16 nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-aid-Hose Reels.			
	Total numbers on each floor/basement	01 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	05 mm	Provided	MR
07	Automatic fire detection and alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of main panel	N/A	N/A	N/A
	Location of repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	size of riser/down-comer	N/A	N/A	N/A
	Number of hydrants per floor	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	Ground Level	N/A	N/A	N/A
	Discharge of main Pump	N/A	N/A	N/A
	Head of Main Pump	N/A	N/A	N/A
	Number of main pumps	N/A	N/A	N/A
	Jockey pump out put	N/A	N/A	N/A
	Jockey pump head	N/A	N/A	N/A
	Standby pump out put	N/A	N/A	N/A
	Standby pump Head	N/A	N/A	N/A
	Auto Starting /Manual stopping	N/A	N/A	N/A
	Pump House Access	N/A	N/A	N/A
	Terrace Level			
	Discharge of pump	450 LPM	450 LPM	MR
	Head of the Pump	40 M	40 M	MR
	Power supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	15000 10,000 Ltr.	15000 Ltr. 10,000 Ltr.	MR
15	Exit Signage.	Required	provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:-	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety require as per circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education, it is recommended to renewal Fire Safety Certificate under rule 37 of the Delhi Fire Service Rules, 2010.


 (Nagender Singh)
 (ADO Shahdara)

Dy. CEO (NDZ)


Pl. Appear about point no. 14.


 24/5/21



ADOC/shan

Needful done. file is resubmitted please



 16/7/21

Dy. CEO (NDZ)


 13/7/21

ADOC/shan

FT letter is placed for signatures ~~ADOC~~


 20/7

Dy. CEO (NDZ)


 22/7/21