

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2021/SZ/339

Dated: 20-07-2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s DEEPSONS SOUTH END located at M-10, South Extension-II, New Delhi-110049, comprised of Basement (Storage Only), Ground Floor & 3 Upper Floors (Shops) owned / occupied by M/s DEEPSONS SOUTH END, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2018/SZ/1824 dated 06/08/2018. The premises was re-inspected by the officer concerned of this department on 30/06/2021 in the presence of Sh. Laxman Singh Bisht and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Mercantile" with effect from 20 / 07 / 2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 20-07-2021.... at New Delhi by.



(SUNIL CHAWDHARY)

DY. CHIEF FIRE OFFICER (S.Z.).

Copy to:-

o/c DEEPSONS

1. Authorized Signatory, M/s DEEPSONS SOUTH END, M-10, South Extension-II, New Delhi-110049.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).



## INSPECTION REPORT

1. Name & address of the building: **M/s DEEPSONS SOUTH END, M-10, South Extension-II, New Delhi-110049.**
2. Type of Occupancy : Mercantile (Basement + Ground & 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2018/SZ/1824 dated 06/08/2018
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 30/06/2021
7. Name of the Inspecting Officer : ADO (S.J.)
8. Name and designation of Officer from the building side : Sh. Laxman Singh Bisht
9. Year of Construction : 2000

10. Applicant's letter received through email [ID-laxmanbisht82@gmail.com](mailto:ID-laxmanbisht82@gmail.com) dated 15/06/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	6 mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	Provided	MR (Old Case)
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.25 mtr	1.25 mtr	MR
	• Basements	1.25 mtr	1.15 mtr & 1.10 mtr	MR (Old Case)
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Required	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.00mtr	0.90 mtr	MR (Old Case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per Hour	Exhaust Fan Provided	MR
	• Upper floors	12 a/c per Hour	Natural Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	16	16	MR
	• Types	ABC/CO <sub>2</sub>	Provided	MR
	• ISI marking	Required	Provided	MR

*AS*



	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Required	Smoke Type	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Each Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	01	01	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM & 180 LPM	900 & 180 LPM	MR
	➤ Head of the pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	40,000 Ltr	Provided	MR
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR



15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2018/SZ/1824 dated 06/08/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*Ashok Jaiswal*  
20/7/2021

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (S.J.)

*D.O. (S.J.)*

*Divy*  
12/07/21

*DFO (S2)*

*F.F. palus*

*F.T. is put up for sign-kl.*

*A.D.O. (S.J.)*

*Dy CPO (S2)*

*Ashok*  
20/7/2021