

C-40

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2021/ 152

Dated: 26/7/21

FIRE SAFETY CERTIFICATE

Certified that the EIH Limited, Unit: Oberoi Flight Services located at IGI Airport Complex, New Delhi-110037, comprised of Basement, Ground & 1st Floor was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Indl./2018/SZ/2176 dated 24/09/2018. The premises was re-inspected by the officers concerned of this department on 14/06/2021 in the presence of Sh. Edmund Fernandes (GM) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Industrial" (Group-G) with effect from 26 / 7 /2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on26/7/21..... at New Delhi by.


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.)

Copy to:-

1. M/s EIH Limited, Unit: Oberoi Flight Services, IGI Airport Complex, New Delhi-110037.
2. DHO, South MCD, Public Health Department, Najafgarh Zone, Dhansa Stand, Najafgarh, New Delhi-110043.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : **EIH Limited, Unit: Oberoi Flight Services, IGI Airport Complex, New Delhi-110037.**
2. Type of Occupancy : Industrial (Group – G)
3. Type of Case : Renewal (**Basement, Ground & 1st Floor**)
4. Details of previous NOC : F6/DFS/MS/Incl./2018/SZ/2176 dated 24/09/2018
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2010/1545 dated 30/05/2010
6. Date of inspection : 14/06/2021
7. Name of the Inspecting Officers : Dy. C.F.O. (S.Z.) & A.D.O. (S.J.)
8. Name and designation of Officer from the building side : Sh. Edmund Fernandes (GM)
9. Year of Construction : 2011
10. Applicant's letter received through MHA portal ID-2021050413284 Dated 28/05/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NFPA /Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	Provided	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	NA	6m	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	1.50 m	1.35m, 1.67m, 1.4m & 1.65m	MR (Old Case)
	• Basements	1.50 m	1.33m & 1.4m	MR (Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	4	4	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	1.6m (Final Exit)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 ACPH	Exhaust Fan	MR
	• Upper floors	12 ACPH	Exhaust Fan	MR
5.	Fire Extinguishers			
	• Total numbers	50	52	MR
	• Types	ABC/CO ₂ /WCO ₂ /Foam/DCP	ABC/CO ₂ /WC O ₂ /Foam/DCP	MR
	• ISI marking	ISI	Provided	MR

6.	First - Aid Hose Reels			
	• Total numbers on each floor	BF-2,GF & UF-5	Provided	MR
	• Length of hose reel hose	30 Mtr.	45 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Required	Security Room	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	BF-2,GF & UF-5	Provided	MR
	• Hose Box	BF-2,GF & UF-5	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	6	Provided	MR
	• Hose Box	6	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 LPM	Provided	MR
	➤ Head of main pump	65 m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	65m	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	65m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR


14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	1,00,000 ltr	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 flooding required in HT & LT Panel	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/Indl./2018/SZ/2176 dated 24/09/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Signature of the Inspecting Officer
Name : Sunil Chawdhary
Designation: Dy.C.F.O. (S.Z.)



Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

ABO (Sf)