

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**


No. F6/DFS/MS/School/WZ/2021/ 522

Dated: 23/7/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C. Primary School**, Located at **G-Block, Shakurpur, JJ Colony, Delhi-110034**, comprised of **02 Block (BL-1=Ground Floor & BL-2=Ground + 01 Upper Floors)** was issued FSC by this department Vide Letter No. F6/DFS/MS/School/2017/1584 dated 07.11.2017. The said premises was re-inspected by the officer concerned of this department on 14.07.2021 in the presence of Ms. B. Pyingili (Principal) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.3298-3398 dated 01-03-2011 and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 23/7/21 for a period of three years, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 23/7/21 at New Delhi by.

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, M.C. Primary School, Located at G-Block, Shakurpur, JJ Colony, Delhi-110034.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

**Shakurpur, JJ Colony, Delhi-110034.**

2. Type of Occupancy : Educational 02 Block (BL-1=Ground Floor & BL-2=G + 01 Upper Floor )
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/1584 dated 07.11.2017
5. Fire Safety directives Letter No. : D.O.E Circular no.3298-3398 dated 01-03-2011
6. Date of inspection : 14.07.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP)
8. Name and designation of Officer  
from the building side : Ms. B. Pyingili (Principal)
9. Year of Construction : 2005
10. Applicant's letter No. :email dated 01.07.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/ letter dated 07.11.2017	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	540 cm	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	BL-2=02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150cm	BL-2=1x192 cm & 1x155 cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	215 cms	MR
	f. Door Size	1 m	111 cms	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	07 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA



	<ul style="list-style-type: none"> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Draw off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pressurization of lift lobby</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Communication in lift Car</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fireman's Grounding Switch</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Flow Switch Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ PA System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Battery backup</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2017/1584 dated 07.11.2017 is recommended.

S.P. Bhardwaj  
ADO (WP)

*[Signature]*  
14/7/21

~~Boxrent~~

~~dy~~  
14/07/2021

D.O. (WESTY) 157  
DATED 14/07/2021

~~DEFO (WZ)~~

*[Signature]*  
16/7/2021

~~ADOF~~

FF is put up for signat per

~~Defot WZ~~

*[Signature]*  
23/7/2021

*[Signature]*  
21/7/21

msf cell