

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2021/SZ/ 531

Dated: 26/07/2021

FIRE SAFETY CERTIFICATE

Certified that the building SDMC Primary School (Girls & Boys), located at Manglapuri-I & II, Palam, New Delhi-110045 comprised of Ground + One Upper Floor owned / occupied by SDMC was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/2017/SZ/669 Dated 09/05/2017. The premises was re inspected by the officer concerned of this department on 07/07/2021 in the presence of Ms. Jokhima Tirkey (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class B "Educational building" with effect from 26/7/21 for a period of three years, subject to condition given below.

Issued on 26/7/21 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal SDMC Primary School (Girls & Boys), located at Manglapuri-I & II, Palam, New Delhi-110045 (School Id-1757158)
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

- 1 **The FSC shall be null & void if pota cabin is used for school activities.**
- 2 **Pota cabins seen in the school premises shall not be used for school activities.**
- 3 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 4 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 5 The trained staff should be available round the clock.
- 6 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 7 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 8 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 9 Basement shall be used strictly as per building bye laws.
10. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

3. Name & address of the building: SDMC Primary School (Girls& Boys), located at Manglapuri-1 &II, Palam, New Delhi-110045
4. Type of Occupancy : Educational (Ground + 01 Upper Floor)
5. Type of Case : Renewal
6. Details of previous NOC : F.6/DFS/MS/School/2017/SZ/669 Dated 09/05/21017
7. Fire Safety directives Letter No. : DOE Circular 3298 -3398 Dated 01/03/2011
8. Date of inspection : 07/07/2021
9. Name of the Inspecting Officer : ADO (DWK)
10. Name and designation of Officer from the building side : Ms. Jokhima Tirkey (Principal)
11. Year of Construction : Before 2010
12. Applicant's letter No. : Nil Dated- 23/06/2021

No. of Students=299
 No. of class rooms=16
 Plot area=5020 m²
 Covered area=3000 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular dated 1/03/2011 As per N/5	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtrs	10 mtr	MR
		4.5mtrs	Directly accessible from road	MR
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	02 No's	02 No's	MR
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1.5 m if less 1.5 mtr additional staircase of 0.75 mtr is required	1.64 & 1.82 mtr	MR (Old case)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace			
		NA	NA	NA
	e. Width Of Corridor			
		NA	NA	NA
	f. Door Size			
		01 mtr	01 mtr including door frame	MR (Old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

N/20

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	CO2 Fire Extinguisher provided near electric meter	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2017/SZ/669 Dated 09/05/21017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- Pota cabins are also seen in the school premises. If agreed FSC may be issued to only one block without pota cabins.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation AD/DW/K

D.O/S/O

14/07/2021 F. D. P. L.
 by CFD/SZ
A D/DW/K