

CB

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2021/ 148

Dated: 23.07.2021

**FIRE SAFETY CERTIFICATE**

Certified that **the My Bar Adda** at ground floor **Shop no. 15-17**, Lady Harding Road, Gole Market, New Delhi, building is comprised of Ground + 02 upper floors **but Restaurant running at ground floor shops**. The premises was inspected by officer concerned of this department on **07/07/2021** in the presence of Mr. Gurvinder and found that the said premises has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D for Restaurant at ground floor only**, with effect from ~~23/7/21~~ for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~23/7/21~~ at New Delhi by.

*Atul Garg*  
23/07/2021

(Atul Garg)

**DIRECTOR**

Delhi Fire Service

Copy to:-

1. The Dy. Commissioner of Police(Lic) , Ist floor, PS Defence Colony , New Delhi  
Online ID no. 2021041212793 dated 14.04.21
2. The Executive Engineer , NDMC , Palika Kendra , New Delhi
3. The Manager,  
M/S My Bar Adda  
Shop No 15-17, Lady Harding Road Gole Market, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is strictly prohibited.
10. This Fsc is valid only for ground floor.

**INSPECTION REPORT**

1. Name & address of the building : M/S My Bar Adda at shops no 15-17 Lady Harding Road , Gole Market New Delhi
2. Type of occupancy:- : Assembly occupancy Group-D  
Building is ground + 02 upper floors  
**Restaurant running at Ground floor Only**
3. Type of case:- : New
4. Details of previous FSC:- :N/A
5. Fire safety directives No.- :N/A
6. Date of inspection:- :07.07.2021
7. Name of the inspecting officer:- : Sh. Rajinder Atwal (DO/CD) & :Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer from the building side:- :Mr.Gurvinder Singh
9. Year of construction:- :old building
10. Applicant's letter No:- :online ID no 2021041212793dated 14.04.2021

| S.No.     | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirements/ Existing fire safety arrangements | Provided at site | Remarks MR/NMR |
|-----------|---|---|------------------|----------------|
| <b>1.</b> | <b>Access to Building</b>                                   |   |                  |                |
|           | 1) Road width   | 06 mtr  | 06 mtr.          | MR             |
|           | 2) Gate width   | N/A   | N/A              | N/A            |
|           | 3)Width of internal road                                    | N/A   | N/A              | N/A            |
| <b>2.</b> | <b>Number, Width Type &amp; Arrangement of Exits</b>        |   |                  |                |
|           | A. Number of staircases                                     |   |                  |                |
|           | 1. Upper floors   | N/A   | N/A              | N/A            |
|           | 2. Basements  | N/A   | N/A              | N/A            |
|           | B. Width of staircase                                       |   |                  |                |
|           | 1. Upper floors (Mezzanine)                                 | N/A   | N/A              | N/A            |
|           | 2. Basements  | N/A   | N/A              | N/A            |
|           | C. Protection of exits                                      |   |                  |                |
|           | 1. Fire check door  | N/A   | N/A              | N/A            |
|           | 2. Pressurization   | N/A   | N/A              | N/A            |
|           | D. No. of continuous staircase to terrace                   |   |                  |                |
|           | E. Width of corridor  | N/A   | N/A              | N/A            |
|           | F. Door size  | 1.5 mtr.  | 2, 1.5 mtr.      | MR             |
| <b>3.</b> | <b>Compartmentation</b>                                     |   |                  |                |
|           | 1) Fire check door  | N/A   | N/A              | N/A            |
|           | 2) Sealing of electrical shafts                             | N/A   | N/A              | N/A            |
|           | 3) Fire rating of shaft door                                | N/A   | N/A              | N/A            |
|           | 4) Water curtain  | N/A   | N/A              | N/A            |
|           | 5) Fire Dampers   | N/A   | N/A              | N/A            |
| <b>4.</b> | <b>Smoke Management System</b>                              |   |                  |                |
|           | 1) Basements  | N/A   | N/A              | N/A            |
|           | 2) Upper floors   | 12 ACPH   | Natural          | MR             |
| <b>5.</b> | <b>Fire Extinguishers</b>                                   |   |                  |                |
|           | 1) Total numbers  | 04 Nos.   | 04 Nos.          | MR             |
|           | 2) Types  | ABC & CO2                                       | ABC & CO2        | MR             |
|           | 3) ISI marking  | Required  | Provided         | MR             |
| <b>6.</b> | <b>First-Aid Hose Reel</b>                                  |   |                  |                |
|           | 1) Total number of each                                     | 01  | 01               | MR             |



|            |   |             |             |     |
|------------|---|-------------|-------------|-----|
|            | floor   |             |             |     |
|            | 2) Length of hose reel hose                           | 30 mtr.     | 30 mtr.     | MR  |
|            | 3) Nozzle diameter                                    | 05 mm       | 05 mm       | MR  |
| <b>7.</b>  | <b>Automatic Fire Detection &amp; Alarming System</b> |             |             |     |
|            | 1) Type of detectors                                  | N/A         | Provided    | N/A |
|            | 2) Location of main panel                             | N/A         | Gr. floor   | N/A |
|            | 3) Location of repeater panel                         | N/A         | N/A         | N/A |
|            | 4) Alternate source of power                          | N/A         | N/A         | N/A |
|            | 5) Hooter's Location                                  | N/A         | N/A         | N/A |
| <b>8.</b>  | <b>MOEFA</b>  | Required    | Provided    | MR  |
| <b>9.</b>  | <b>Public Address System</b>                          | Required    | Provided    | MR  |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                     |             |             |     |
|            | 1) Basement   | N/A         | N/A         | N/A |
|            | 2) Upper floors                                       | N/A         | Provided    | N/A |
|            | 3) Sprinkler above false ceiling                      | N/A         | N/A         | N/A |
| <b>11.</b> | <b>Internal Hydrants</b>                              |             |             |     |
|            | 1) Size of riser/down-comer                           | 100 mm      | 100 mm      | MR  |
|            | 2) Number of hydrants per floor                       | 01          | 01          | MR  |
|            | 3) Hose box   | 02          | 02          | MR  |
| <b>12.</b> | <b>Yard Hydrants</b>                                  |             |             |     |
|            | 1) Total number of hydrants                           | N/A         | N/A         | N/A |
|            | 2) Hose box   | N/A         | N/A         | N/A |
| <b>13.</b> | <b>Pumping Arrangement</b>                            |             |             |     |
|            | 1) Ground level                                       | N/A         | N/A         | N/A |
|            | a) Discharge of main pump                             | N/A         | N/A         | N/A |
|            | b) Head of main pump                                  | N/A         | N/A         | N/A |
|            | c) Number of main pump                                | N/A         | N/A         | N/A |
|            | d) Jockey pump out put                                | N/A         | N/A         | N/A |
|            | e) Jockey pump head                                   | N/A         | N/A         | N/A |
|            | f) Stand by pump output                               | N/A         | N/A         | N/A |
|            | g) Stand by pump head                                 | N/A         | N/A         | N/A |
|            | h) Auto starting/Manual stopping                      | N/A         | N/A         | N/A |
|            | 2) Terrace level                                      |             |             |     |
|            | a) Discharge of pump                                  | 450 LPM     | 450 LPM     | MR  |
|            | b) Head of pump                                       | 30 mtr.     | 30 mtr.     | MR  |
|            | c) Power supply                                       | Required    | Provided    | MR  |
|            | d) Auto starting of pump                              | Required    | Provided    | MR  |
| <b>14.</b> | <b>Captive Water Storage for Fire Fighting</b>        |             |             |     |
|            | 1) Under ground tank capacity                         | N/A         | N/A         | N/A |
|            | a) Draw-off connection                                | N/A         | N/A         | N/A |
|            | b) Fire service inlet                                 | N/A         | N/A         | N/A |
|            | c) Access to tank                                     | N/A         | N/A         | N/A |
|            | d) Over head tank                                     | 20,000 ltr. | 20,000 ltr. | MR  |

|     | capacity  |          |          |     |
|-----|---|----------|----------|-----|
| 15. | <b>Exit Signage.</b>  | Required | Provided | MR  |
| 16. | <b>Provision of Lifts.</b>  |          |          |     |
|     | a) Pressurization of lift shaft   | N/A      | N/A      | N/A |
|     | b) Pressurization of lift lobby   | N/A      | N/A      | N/A |
|     | c) Communication in lift car  | N/A      | N/A      | N/A |
|     | d) Fireman's switch   | N/A      | N/A      | N/A |
|     | e) Lift signage   | N/A      | N/A      | N/A |
| 17. | <b>Stand by Power Supply</b>  | Required | Provided | MR  |
| 18. | <b>Refuge Area</b>  | N/A      | N/A      | N/A |
|     | Total area location   | N/A      | N/A      | N/A |
| 19. | <b>Fire Control Room</b>  | N/A      | N/A      | N/A |
|     | a) Detector system panel  | N/A      | N/A      | N/A |
|     | b) Flow switch panel  | N/A      | N/A      | N/A |
|     | c) PA system panel  | N/A      | N/A      | N/A |
|     | d) Battery backup   | N/A      | N/A      | N/A |
|     | e) Building floor plan  | N/A      | N/A      | N/A |
| 20. | <b>Special Fire Protection System for Protection of special Risk, if any:</b> |          |          | NA  |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, if agreed, the fire Safety Certificate under rule 35 of Delhi Fire Service Rules-2010 is recommended to for approval.

Signature of the Inspecting Officer

*[Handwritten Signature]*  
9/7/21

Name: - Rajinder Atwal  
Designation: - DO (CD)

Signature of the Inspecting Officer

*[Handwritten Signature]*  
9/7/21

Name: - Ravinder Singh  
Designation: - ADO (CC)



*[Handwritten Signature]*  
Dy CPO (MD2)  
*[Handwritten Signature]*  
13/7/21

*[Handwritten Signature]*  
CFO/MD2

*[Handwritten Signature]*  
25/7

*[Handwritten Signature]*  
11/7

*[Handwritten Signature]*  
16/07/21  
*[Handwritten Signature]*  
DO/CD