

C-67

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/2021/EH/ 150

Dated: 23/7/21

FIRE SAFETY CERTIFICATE

Certified that the McDonalds Family Restaurant Pvt. Ltd. at G-2A Unit No. 104, running on Ground & Mezzanine floor, Dilshad Garden Metro Station Complex, Delhi 110095, the building is comprised of ground plus two upper floors, owned/occupied by Mc Donalds Family Restaurant Operated by M/s Connaught Plaza Restaurant Pvt .Ltd. was granted FSC vide Letter no.F6/DFS/MS/EH/2016/1633 dated 04/11/2016. The restaurants building was re-inspected by the officer concerned this department in the presence of Sh. Mukesh Kumar, Manager of the restaurant and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the eating house building is fit for ground & mezzanine floor occupancy class "D" 'Assembly Building' with effect from 23.7.21 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on..... at New Delhi by


13/7/21

(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,

The Manager
Mc Donalds Family Restaurant Pvt. Ltd.
G-2A Unit No. 104, Ground & Mezzanine floor
Dilshad Garden Metro Station Complex
Delhi 110095

MHA ID No. 2020112808718

Conditions for the validity of Fire Safety Certificate

1. This NOC is valid for Ground & Mezzanine floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Mc Donalds Family Restaurant Pvt. Ltd.
Shop No. 4, Ground & Mezzanine Floor
Dilshad Garden Metro Station, Delhi-110095
2. Building is comprised of : Ground Plus Two upper floors
(Restaurant on Ground & Mezzanine Floor)
3. Type of Occupancy : Restaurant (Assembly)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/EH/2016/1633 dated 04/11/16
6. Fire Safety directive letter No : NBC Part IV
7. Date of Inspection : 03/07/2021
8. Name of the Inspecting officers : A.D.O. Mehmood
9. Name and designation of Officer
from the building side : Sh. Mukesh Kumar(Manager)
10. Year of Construction : 2008
11. Applicant's letter No : 2020112808718, Dated- 19/06/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part- IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12 mtr.	28 mtr.	MR
	• Gate width	4.5 mtr.	06 mtr.	MR
	• Width of internal road	06 mtr.	06 mtr.	MR
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr.	1.55 mtr & 1.0 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	2.12 & 2.0 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Provided	MR
05.	Fire Extinguishers			
	• Total numbers	03 nos.	12 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System			
	• Type of detectors	N/A	Smoke/Heat	MR
	• Location of main panel	N/A	Provided	MR
	• Location of repeater panel	N/A	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter	Near Gate	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	Common with Metro Station		
	• Discharge of main pump	1800 lpm	Provided	MR
	• Head of main pump	40 mtrs	Provided	MR
	• Number of main pumps	02 nos	Provided	MR
	• Jockey pump out put	180 lpm	Provided	MR
	• Jockey pump head	40 mtr	Provided	MR
	• Standby pump out put	1800 lpm	Provided	MR
	• Standby pump head	40 mtr	Provided	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	50,000 ltrs	50, 000 ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection. The shortcomings communicated vide letter No. F6/DFS/MS/NDZ/2020/219 dated 21/02/2020 have already been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures required under the rule the FSC issued vide letter No. F6/DFS/MS/EH/2016/1633 dated 04/11/16, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended to renew Fire Safety Certificate.

Mehmood
18/2/20

Signature of the Inspecting Officer
Name : Mehmood
Designation : A.D.O. (TP)

Dy. CFQ (NDZ)



K Tomar
15/7/21

ADD (TP)

Sr.

A dt letter pur. by the by no. 1/19

Dy. CFQ (NDZ)

K Tomar
15/7/21

Mehmood
19/2/20

ADD (TP)