

C-72

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/WZ/2021/ 551

Dated: 28 / 7 / 2021

FIRE SAFETY CERTIFICATE

Certified that the **Rising Star Academy Senior Secondary School** Located at **110, Raj Nagar, Pitampura, Delhi-110034** comprised of Ground + 03 Upper Floors was issued Fire Safety Certificate by this department vide Letter No. F6/MS/DFS/School/2018/WZ/1881 Dated 09.08.2021. The said premises was re-inspected by the officer concerned of this department on 20.07.2021 in the presence of Sh. Pradeep (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirement an accordance with rule 33 of the Delhi Fire Services Rules 2010 & that the premises is fit for occupancy class "Educational" Group B with effect from 28/7/21 for a period of **three years**, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 28/7/21 at New Delhi by.

DL

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

[Handwritten signature]
28/7/2021

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054. *[Handwritten mark]*
2. The Principal, Rising Star Academy Senior Secondary School Located at 110, Raj Nagar, Pitampura, Delhi-110034.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

1. Name & address of the building: **Rising Star Academy Senior Secondary School**
Located at **110, Raj Nagar, Pitampura, Delhi - 110034**
2. Type of Occupancy : Educational (Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SCHOOL/2018/WZ/1881 Dated 09.08.2018
5. Fire Safety directives Letter No. : D.O.E Circular 262-362 dated 17.01.2005/N-6
6. Date of inspection : 20.07.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj, ADO (WP).
8. Name and designation of Officer
from the building side : Sh. Pradeep (Manager)
9. Year of Construction : 2002
10. Applicant's letter No. : RSA/2021/06/89 dated 02.07.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 17.01.2005/letter dated 09.08.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	5m Provided	MR
	• Gate width	Accessible	5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2X1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1 m	107cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	08nos.	19 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR

Automatic fire detection and alarming system				
7.	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	Required	100 mm	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm&180 Lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
➤ Auto starting of pump	Required	Provided	MR	
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	50000 ltrs	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/SCHOOL/2018/WZ/1881 Dated-09.08.2021 is recommended under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

~~DO/WZ~~

S.P. Bhardwaj, ADO (WP)
Suy 22/7/21

~~DO~~
 22/7/2021

~~DCFO (WZ)~~

28/7/2021

D.O. (WEST)/156
 DATED. 22/07/21

~~AD/WZ~~

AT is put up for sanction per

~~DO/WZ~~
 28/7/2021

Suy
 28/7/21

~~AD/Cell~~