

C-34

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2021/ 157

Dated: 28/07/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Restaurant/Eating House** located at **Swaminarayan Akshardham, H.H.-24, off. Nizamuddin Bridge, Akshardham Setu, New Delhi-92** comprises of **Ground + 01 Upper floor**, owned/occupied by **M/s Suvasini Charitable Trust**, was granted FSC by this department vide letter No. **F6/DFS/MS/EH/2017/NDZ/982** dated **10/07/17**. The premises was re-inspected by the officer concerned of this department on **22/07/21** in the presence of **Mr. Jayesh Gadhia (Manager)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Assembly Building Group D (Restaurant)** with effect from ~~28/7/21~~ for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued ----- ~~28/7/21~~ at New Delhi by

  
27/7/21

(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

- 1 M/s Suvasini Charitable Trust,  
Swaminarayan Akshardham,  
N.H.-24, off. Nizamuddin Bridge, Akshardham Setu, New Delhi-92.  
Online application ID no. 2021040912640 .
2. The Dy. Health Officer,  
EDMC Health Departement, Shahadra (South Zon), Karkardooma, Shahadara, Delhi.

**Condition for the validity of fire safety certificate**

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
- 9 Any flammable material for interior decoration is prohibited.

**INSPECTION REPORT**

- |  |   |
|--|---|
| 1. Name & address of the building                            | Restaurant/Eating House located at<br>Swaminarayan Akshardham, H.H.-24, off.<br>Nizamuddin Bridge, Akshardham Setu, New<br>Delhi-92 |
| 2. Type of occupancy:-                                       | Assembly Building Group-D<br>Ground + 01 Upper floor  |
| 3. Type of case:-  | Renewal   |
| 4. Details of previous FSC:-                                 | No. F6/DFS/MS/EH/2017/NDZ/982 dated<br>10/07/17   |
| 5. Fire safety directives No.-                               | NBC Part-IV   |
| 6. Date of inspection:-                                      | 22/07/21  |
| 7. Name of the inspecting officer:-                          | Sh. Manoj Kumar Sharma (ADO/LN)   |
| 8. Name & designation of officer<br>from the building side:- | Mr. Jayesh Gadhia (Manager)   |
| 9. Year of construction:-                                    | 2009  |
| 10. Applicant's letter No:-                                  | ID no. 2021040912640 dated 11/06/2021   |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC (Old)	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	12 mtr	30 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	02 nos.	03 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1.35, 1.35 & 1.46 mtr.	MR (Old Case)
	2. Basements	N/A	N/A	N/A
	C. Protection of exits	N/A	N/A	N/A
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	2.0 mtr.	3.0 mtr.	MR
	F. Door size	2.0mtr.	3.0 & 1.8 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Sealed	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	08 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	02 nos.	03 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR

7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	Heat & smoke	N/A
	2) Location of main panel	N/A	Provided	N/A
	3) Location of repeater panel	N/A	Provided	N/A
	4) Alternate source of power	N/A	Provided	N/A
	5) Hooter's Location	N/A	Provided	N/A
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	02 nos.	03 nos.	MR
	3) Hose box	02 nos.	03 nos.	MR
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	1,00,000 liter	N/A
	a) Draw-off connection	N/A	Provided	N/A
	b) Fire service inlet	N/A	Provided	N/A
	c) Access to tank	N/A	Provided	N/A
	d) Over head tank capacity	10,000 ltr.	35,000 ltr.	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A

N/27

	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	<b>Stand by Power Supply</b>	Required	Provided	MR
18.	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. As directed undertaking in r/o staircases received from Akshardham temple and put up opposite.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/EH/2017/NDZ/982 dated 10/07/17, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

Signature of the Inspecting Officer

*M.K. Sharma*  
27/7/21


Name :- M.K. Sharma  
Designation :- ADO (LN)

Dy.CFO/NDZ

F.T. pl.

*A.K. Tomer*  
23/7/21

*A DO (LN)*



*F.T. letter is put up for org. pl*

*M.K. Sharma*  
27/7

*Dy CFO (NDZ)*

*A.K. Tomer*  
27/7/21