

C-82

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2021/S/546

Dated: 28/07/2021

FIRE SAFETY CERTIFICATE

Certified that the Delhi Kannada Senior School No-3 at Lodhi Estate, New Delhi-110003 having two blocks, A-Blocks, A-Block (Secondary) comprised of Ground & Three Upper Floors and B-Block (Primary) Comprised of Ground & Two Upper Floors owned / occupied by Delhi Kannada Education Society (Reed.) has already been issued Fire Safety Certificate Vide letter No. F6/DFS/MS/School/2018/S/2650 dated 10/12/2018. The premises was re-inspected by the officer concerned of Fire Service on 20/07/2021 in the presence of Sh. Parshant Kumar (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "Educational" (Group-B) with effect from 28 / 07 / 2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 28/07/2021 at New Delhi by.


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Principal, Delhi Kannada Senior School No-3, Lodhi Estate, New Delhi-110003.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the manager.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Delhi Kannada Senior School No-3, Lodhi Estate, New Delhi-110003.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC No. F6/DFS/MS/School/2018/SZ/2650 dated 10/12/2018
5. Fire Safety directives Letter No. : D.O.E. Circular No.262-362 Dated 17/01/2005
6. Date of inspection : 20/07/2021
7. Name of the Inspecting Officer : A.D.O. (S.J.)
8. Name and designation of Officer
from the building side : Mr. Parshant Kumar (Principal)
9. Year of Construction : 1995
10. Applicant's letter received through email ID-dkes1959@gmail.com dated 07/07/2021

A Block - Ground + 3 Upper F. & B Block - Ground + 2 Upper F.
--

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr	12 mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos Each BK	Provided	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50 m / 0.90m	A Bk-1.55m each B Bk- 1.2m, 1.5m iron	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	01 each block	Provided	MR
	c. Width Of Corridor	1.5m	Provided	MR
	d. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 ACPH	NA	NA
	• Upper floors	12 ACPH	NA	NA
5.	Fire Extinguishers			
	• Total numbers	Required	22	MR
	• Types	ABC /Co ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR

ABC

	• Total numbers on each floor	1 each Bk	1	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	01 each Bk	Provided	MR
	• Hose Box	01 each Bk	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	01 each Block	A-Bk-01, B- Bk-02	MR
	➤ Discharge of pump	450LPM	A BK-450 LPM B BK-450 & 180 LPM	MR
	➤ Head of the pump	40 MH	40 MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA

21-21

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2018/SZ/2650 dated 10/12/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok
22/07/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

~~DD(SD)~~

Div
22/07/21

~~DD(S2)~~

F.I. please

[Signature]

~~ADD(S.J.)~~