

G32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**


No.F.6/DFS/MS/EH/2021/SZ/ 155

Dated: 28/7/21

**FIRE SAFETY CERTIFICATE**

Certified that the **Burger King India Pvt. Ltd.**, Unit No.-GF-05, Orchard Road, Janak Puri West Metro Station, New Delhi-110058, two Basements, Ground plus eight upper floors & terrace but restaurant is at ground floor only, was issued FSC by this department vide letter no. F6/DFS/MS/EH/2019/SZ/958 dated 08/05/2019 owned/occupied by Burger King India Pvt. Ltd. The restaurant building was re-inspected by the officers concerned of this department on 22/07/2021 in the presence of Sh. Etin (Store Manager) and found that Management of Burger King India Pvt. Ltd have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises **(Ground Floor Only)** is fit for occupancy class Group-D "Assembly Building" w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....28/7/21..... at New Delhi.

  
(SUNIL CHAUDHARY)  
DY.CHIEF FIRE OFFICER  
OKR

Copy to:-

1. The Manager,  
Burger King India Pvt. Ltd., Unit No.-GF-05,  
Orchard Road, Janak Puri West Metro Station, New Delhi-110058
2. The Dy. Health Officer,  
S.D.M.C, Public Health Department, West Zone,  
Vishal Enclave, Rajouri Garden, New Delhi-110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Burger King India Pvt. Ltd., Unit No.-GF-05, Orchard Road, Janak Puri West Metro Station, New Delhi-110058.
2. Type of Occupancy : Group D (Assembly)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2019/SZ/958 dated 08/05/2019
5. Fire Safety directives letter No : N/A
6. Date of inspection : 22/07/2021
7. Name of Inspecting Officers : A.D.O. R.K.Yadav
8. Name and designation of officers  
From the building side : Sh. Etin (Store Manager)
9. Year of Construction : 2015
10. Applicant's letter No. : ID No. 2021042213138 dated 12/07/2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	09 mtrs. 06 mtrs. 06 mtrs.	Provided Provided Provided	M/R M/R M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>(Restaurant at GF only)</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	03 No's 03 No's	03 No's 03 No's	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.5 m each 1.5 m each	1.5 m (03 no's) 1.5 m (03 no's)	M/R M/R
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required Required	Provided Provided	M/R M/R
	d. No. of continuous staircases to terrace			
		Required 1.5 m	Provided Opening in hall	M/R M/R
	e. Width of Corridor			
	f. Door Size	2 m & 1 m	Provided	M/R
3.	<b>Compartmentation</b>			
	<b>(Restaurant at GF only)</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	Required Required 02 hrs Required Required	Provided Sealed Provided Provided Provided	M/R M/R M/R M/R M/R
4.	<b>Smoke Management System</b>			
	<b>(Restaurant at GF only)</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	Required Required	Provided Provided	M/R M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers in restaurant</li> <li>• Types</li> <li>• IS marking</li> </ul>	05 no.'s ABC/CO <sub>2</sub> ISI marked	Provided Provided Provided	M/R M/R M/R
6.	<b>First-Aid Hose Reels</b>			
	<b>(Common with parking cum commercial building)</b>			
	<ul style="list-style-type: none"> <li>• Total numbers for restaurant</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R



7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors Smoke/Heat/Gas</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required Required N/A Required Required	Provided Provided at GF N/A Provided Near exit	M/R M/R N/A M/R M/R
8.	<b>MOEFA</b>	Required	Provided	M/R
9.	<b>Public Address System</b>	Required	Provided	M/R
10.	<b>Automatic Sprinkler System</b>	<b>(Restaurant at GF only)</b>		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	Required Required Required	Provided Provided Provided	M/R M/R M/R
11.	<b>Internal Hydrants</b>	<b>(Common with parking cum commercial building)</b>		
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants for restaurant</li> <li>Hose Box</li> </ul>	150/100 mm One One	Provided Provided Provided	M/R M/R M/R
12.	<b>Yard Hydrants For entire building</b>	<b>(Common with parking cum commercial building)</b>		
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	Seven Seven	Provided Provided	M/R M/R
13.	<b>Pumping Arrangements For entire building</b>	<b>(Common with parking cum commercial building)</b>		
	<ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Water curtain Pump</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> <li>Pump House Access</li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	 2850 LPM 90 mtrs Two 280 LPM 90 mtrs 2850 LPM 90 mtrs 1000 LPM Required Required  900 LPM 40 mtrs Required Required	 Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided Provided  Provided Provided Provided Provided	 M/R M/R M/R M/R M/R M/R M/R M/R M/R M/R M/R  M/R M/R M/R M/R
14.	<b>Captive Water Storage for fire fighting</b>	<b>(Common with parking cum commercial building)</b>		
	<ul style="list-style-type: none"> <li>Underground tank capacity                             <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	2,00,000 ltrs Required Required Required 20000 ltrs	Provided Provided Provided Provided Provided	M/R M/R M/R M/R M/R
15.	<b>Exit Signage.</b>	Required	Provided	M/R
16.	<b>Provision of Lifts.</b>	<b>(Restaurant at GF only)</b>		
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	Required Required Required Required Required	Provided Provided Provided Provided Provided	M/R M/R M/R M/R M/R
17.	<b>Standby power supply</b>	Required	Provided	M/R
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	N/A	N/A	N/A



2/11

Building comprised of two Basements, Ground plus eight upper floors & terrace but restaurant is at ground floor.

19.	<b>Fire Control Room</b>	Required	Provided	M/R
	• Detector System Panel	Required	Provided	M/R
	• Flow Switch Panel	Required	Provided	M/R
	• PA System Panel	Required	Provided	M/R
	• Battery backup	Required	Provided	M/R
	• Building Floor Plans	Required	Provided	M/R
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	Required	Provided	M/R

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the fire safety certificate issued vide letter no. F6/DFS/MS/EH/2019/SZ/958 dated 08/05/2019 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- The restaurant is at ground floor level in the Multi Level Car Parking cum Commercial area, Janak Puri West Metro Station, New Delhi and have common fire safety installations. The FSC was issued to Multi Level Car Parking cum Commercial area vide letter no. F.6/DFS/MS/PRKG/2019/SZ/173 dated 24.01.2019.

*R. K. Yadav*  
22/7/2021

Signature of Inspecting Officer  
Name:- R.K.Yadav  
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

*Dy CPO (S2)*  
*23/07/2021*

*A D of (JKP)*

F T letter & put up for sign please

*DY CPO (S2)*

*R. K. Yadav*  
29/7/2021