

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/Bnqt/2021/NDZ/ 358

Dated: 27/07/2021

FIRE SAFETY CERTIFICATE

Certified that the Ambika Place(Banquet Hall) located at B-3/B Main Wazirabad Road,Bhajanpura,Delhi-110053 running on first, mezzanine and 2nd floor of the building comprised of basement,ground,1stmezzanine and 2nd floor, owned/occupied by Ambika Place(Banquet Hall)was issued FSC vide Letter no.F6/DFS/MS/BNQT/2017/642 dt.04/05/17.The Building was re-inspected by the officer concerned of this department in the presence of Sh. Shashi Kant Aggarwal, Owner and found that the banquet hall have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for first, mezzanine and 2nd floor occupancy class "D" 'Assembly Building' (Banquet Hall) with effect from 27/07/2021 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 27/07/2021 at New Delhi by


22/7/21

(Dr. S.K. Tomar)
Dy.Chief Fire Officer

To,

Sh. Shashi Kant Aggarwal(Owner)
M/s Ambika Place(Banquet Hall)
Delhi-110053

Copy:-

The Dy. Health Officer
EDMC, Public Health Department
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi-110032

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. Name & address of the building : Ambika Place (Banquet Hall), B-3/B,
Main Wazirabad Road, Bhajan Pura, Delhi-110053
2. Building is comprised of : Basement, Ground plus Two Floors (Banquet hall is
running on 1st, Mez. & IInd floor only)
3. Type of Occupany : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/BNOT/2017/642 Dt. 04/05/17
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 12/04/2021
8. Name of the Inspecting officers : ADO Mehmood
9. Name and designation of Officer
from the building side : Mr. Shashi Kant Aggarwal (Manager)
10. Year of Construction : 2003
11. Applicant's letter No : Letter No.-Nil, Dated- 12/03/2021

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	24 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	02 nos	02 nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.50 mtr (Old Building)	3.65 & 1.10 mtr.	MR
	• Basement	1.25 mtr.	1.35 & 0.93 mtr.	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 mtr.	MR
03	Compartmentation.			
	• Fire check door	Not Required	Exit of basement Separated	MR
	• Sealing of electrical shafts	N/A	Conceald type	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Ex. Fan Provoded	MR
	• Upper floor	Required	Ventilated	MR
05.	Fire Extinguishers.			
	• Total numbers	12 nos.	12 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor	01 No.	Provided	MR
	• Length of hose reel hose	30 mtr.	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Required	Provided	MR
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Staircase	Provided	MR
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 No.	01 No.	MR
	• Hose Box per floor	01 No.	01 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280 Lpm.	2280 Lpm.	MR
	➤ Head of Main Pump	40 M	40 M	MR
	➤ Number of main pumps	01 No.	01 No.	MR
	➤ Jockey pump out put	180 Lpm.	180 Lpm.	MR
	➤ Jockey pump head	40 M.	40 M.	MR
	➤ Standby pump out put	2280 Lpm.	2280 Lpm.	MR
	➤ Standby pump Head	40 M.	40 M.	N/A
	➤ Auto Starting /Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	450 Lpm.	450 Lpm.	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 Ltr.	50,000 Ltr.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 Ltr.	10,000 Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

N/107

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rule, it is recommended to Fire Safety Certificate.

Mehmood
15/4/2021

Signature of the Inspecting Officer
Name - Mehmood
Designation - A.D.O (TP)

Dy.CFO(NDZ)

Pl. speak about point No. 7.

Mehmood
15/4/21



ADDO(TP)

spoken on 22/6/2021 at Refuge Area

Mehmood
22/06/2021
(Mehmood)

Refuge Area F.R. pt.

Mehmood
25/6/21

ADDO(TP)

sw to all clear for Refuge Area

Dy.CFO(NDZ)