

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SZ/Pet/2021/ 361

Dated: 28/07/2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Capital Oil Agency (Retail outlet of I.O.C.L. Petroleum Class A & B) located at Ring Road, Sarojini Nagar, New Delhi-110023, Comprised of Ground Floor only owned / occupied by M/s Capital Oil Agency (Retail outlet of I.O.C.L. Petroleum Class A & B) was issued FSC by this office vide letter No. F6/DFS/MS/Pet/2018/SZ/1459 Dated 21/06/2018. The premises was re-inspected by the officer concerned of this department on 03/07/2021 in the presence of Sh. Sh. J.S. Khurana (Manager) and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Storage" (Group-H) (Storage) with effect from 28/07/2021 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 28/07/2021 at New Delhi.

  
(SUNIL CHAUDHARY)  
DY. CHIEF FIRE OFFICER (S.Z.).

Copy to :-

1. Authorized Signatory, M/s Capital Oil Agency (Retail outlet of I.O.C.L. Petroleum Class A & B) located at Ring Road, Sarojini Nagar, New Delhi-110023.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in).

M/14  
**INSPECTION REPORT**

1. Name & address of the building: **M/s Capital Oil Agency (Retail outlet of I.O.C.L. Petroleum Class A & B) at Ring Road, Sarojini Nagar, New Delhi-110023.**
2. Type of Occupancy : Storage (Group-H) Petrol Pump
3. Building comprised of : Ground Floor
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/Pet/2018/SZ/1459 Dated 21/06/2018
6. Fire Safety directives Letter No. : F6/DFS/MS/BP/2017/364 dated 21/12/2017
7. Date of inspection : 03/07/2021
8. Name of the Inspecting Officers : A.D.O. (S.J.)
9. Name and designation of Officer from the building side : Sh. J.S. Khurana (Manager)
10. Year of Construction : 1995
11. Applicant's letter received through email ID-capitaloilagency.vc@gmail.com dated 30/07/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	30mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA		
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Ground /Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	10	12	MR
	• Types	ABC/CO <sub>2</sub> /DCP	Provided	MR
	• ISI marking	Required	Provided	MR

*(Handwritten Signature)*

6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA		
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank, capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA

21-16

15	"No Smoking" Signage	Required	Displayed in Hindi & English	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	DG Set	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring have also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Pet/2018/SZ/1459 Dated 21/06/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*A.K. Jaiswal*  
5/7/2021

Signature of the Inspecting Officer  
Name : A.K. Jaiswal  
Designation : A.D.O. (S.J.)

*DO/SJ*

*Imp*  
*06/07*

*F.T. please.*

*Deft/SJ*

*[Signature]*

*DO/SJ*

*imp. S.*