

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 360

Dated: 28/07/2021

**FIRE SAFETY CERTIFICATE**

Certified that M/s CNG filling station (IGL) Sector-20, Dwarka, New Delhi, in a building comprised of Ground + 01 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/CNG/2018/1744 dated- 27/07/2018. The premises was re inspected by the officers concerned of this department on 05/07/2021 in the presence of Sh. Ajay Kumar Khatri (DGM) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy of CNG Filling Station" with effect from 28/07/2021 for a period of three years ,subject to compliance of the condition printed overleaf.

Issued on 28/07/2021 at New Delhi by.



(Sunil Chaudhary)  
Dy. Chief Fire Officer,  
Delhi Fire Service.

Copy to:

1. Sh. Alok Sharma, Vice President-Fire & Safety IGL Bhawan, Plot No-4, Community Center, R K Puram Sec-9, New Delhi.
2. Shri Arun Kumar Singh, Chairman, Fire & Safety IGL Bhawan, Plot No-4, Community Center, R K Puram Sec-9, New Delhi.
3. M/s CNG Station (IGL) Sector-20, Dwarka, New Delhi

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building: M/s CNG Station (IGL) Sector-20, Dwarka, New Delhi
2. Type of Occupancy : Group J: Hazardous (CNG Filling Station)
3. Type of Case : Renewal (Ground + 1 Upper Floor)
4. Details of previous NOC : F6/DFS/MS/CNG/2018/1744 dated- 27/07/2018.
5. Fire Safety directives Letter No. : OISD -179/ letter dated Dated 24/09/2007
6. Date of inspection :05/07/2021
7. Name of the Inspecting Officer :Sh.Udai vir singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Ajay Kumar Khatri (DGM)
9. Year of Construction : 2014
10. Applicant's letter No. :Email dated 01/07/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/8	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9m	60m	MR
	• Gate width	4.5	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Required	01 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	0.98 mtr	1.25 mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided as per plan	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	1.25 mtr	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	NA
5.	Fire Extinguishers			
	• Total numbers	14 nos.	37 Nos.	MR
	• Types	DCP & CO <sub>2</sub>	Co <sub>2</sub> 4.5 kg ( 8 Nos.) DCP Trolley of 75 kg (11Nos.) DCP 10 kgs. (18 Nos.)	MR
	• IS marking	Required	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	Gas & Flame	Provided in compressor package	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Ground Floor	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA



13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage	Required no smoking board		Provided MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided DG set 25 kva	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA



20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO2 Flooding	Provided for compressor	MR
-----	--	--------------	-------------------------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/CNG/2018/1744 dated- 27/07/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

*Handwritten signature*  
 27/7/21  
 Name *Uma Vir Singh*  
 Designation *ADDPW 4*

*Dofsc*

*by*  
 14/07/2021

*by ch (S)*

*ADDP (WR)*

*Six FT letter is put up for*

*Sign ple*

*Handwritten signature*  
 22/7/21

*Dyefolsz*

*Handwritten signature*

*m.s.*