

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/MN/2021/ 161

Dated: 29/7/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s. The Firangi Grill (Eating House) located at Plot no. 62, Rama Road, Najafagr Road, New Delhi 110015 in a building comprised of Ground floor only Owned/Occupied by M/s The Firangi Grill have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules, 2010 and verified by the officer concerned of this department on 29/06/2021 in the presence of Sh. Ankur Aggarwal and found that the said building is fit for occupancy class "Assembly" Group D (Ground floor Only) with effect from 29/7/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 29/7/21..... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. M/s. The Firangi Grill (Eating House) located at Plot no. 62, Rama Road, Najafagr Road, New Delhi 110015.
2. Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. This NOC is valid for Ground floor only.

1. Name & address of the building : M/S Firangi Grill Located at Plot No. 62, Ground Floor, Rama Road, Najafgarh Road, New Delhi-110015.
2. Type of Occupancy : Class -D(Assembly at Ground Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : Nil
6. Date of inspection : 29/06/2021
7. Name of the Inspecting Officers : Sarabjeet Singh, Asst. Divisional Officer (MN)
8. Name and designation of officers from the building side : Mr. Ankur Kumar
9. Year of Construction : 1977
10. Applicant's letter No. : Email dated 10/06/2021

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	Provided	MR
	• Gate width	05m	Provided	MR
	• Width of internal road	NA	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA (G.F.)	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA (G.F.)	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	2m & 1.5 m	1X210cms&1X153 cms	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers Types IS marking 	4nos, CO2&WCO2 ISI Marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 30m 5mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	Smoke GF NA Provided GF	NA NA NA NA NA
8	MOEFA	Required NA	Provided NA	MR NA
9	Public Address System.			
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA NA NA	NA Provided NA	NA NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150mm 1 1	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 mtr Required Required	NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA MR MR MR MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank 	NA NA NA NA 20,000 liters	NA NA NA NA Provided	NA NA NA NA MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Grounding Switch	NA	NA	NA
	• Lift Communication In lift Car	NA	NA	NA
	• Fireman's Signage	NA	NA	NA
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time inspection. The shortcomings issued by this department vide letter no F6/DFS/MS/EH/WZ/2020/896 Dated 08/12/2020 have been complied.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

1. The total covered area 298.77m²
2. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 166 (298.77/1.8=165.98 say 166) for whole restaurant.

3. The total seating capacity comes out to be 166.

144/ADP/mn³
02/07/2021

~~Signature~~

~~Signature~~
05/07/2021

D.O. (WEST) 127
DATED 05/07/2021

Signature of inspecting Officer
Name : Sarabjeet Singh
Designation:-A.D.O. (M.N.)

~~Signature~~
05/07/2021

~~Signature~~
05/07/2021

~~Signature~~
05/07/2021

