

e-11

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/GH/SZ/2021/ 275

Dated: 2/8/21

FIRE SAFETY CERTIFICATE

Certified that M/s. **Hotel Good Palace** located at **15A/63, WEA , Karol Bagh, New Delhi-110005** comprised of basement, ground plus three upper floors, using basement storage/hall, ground floor as reception & one hall, first floor having 07 guest rooms, second & third floor each having 08 guest rooms respectively, (total 23 guest rooms) and a pantry for staff on terrace was granted FSC by this department vide letter No. F6/DFS/MS/GH/SZ/2018/2333 dated 16.10.2018. The premises was re-inspected by the officer concerned of this department on 13.07.2021 in presence of Sh. Gurvinder Singh, Owner of the guest house, and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) **for basement (storage), ground floor (reception & hall), first floor having 07 guest rooms, second & third floor each having 08 guest rooms respectively (total 23 guest rooms only)** with effect from 2/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed back side.

Issued on 2/8/21 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to:-

1. Sh. Gurvinder Singh (Owner), M/s. Hotel Good Palace, 15A/63, WEA, Karol Bagh, New Delhi- 110005.
2. The Joint C.P. (Lic.), Police Station Defence Colony, 1st floor, New Delhi.

Following Fire Safety Directives must be adhered to: -

1. **The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/359-374 dated 29.06.2021 in respect of existing building (copy enclosed) shall be implemented by 30.09.2021 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void**
2. No occupancy above third floor & basement as storage purpose, shall be adhered by Owner/Occupier
3. All the means of escape shall be kept free of all type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
7. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
8. All comments / directions of licensing department shall always be permitted and followed.
9. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
10. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
11. Basement shall be used as per BBL.
12. No temporary shed is allowed on terrace.
13. The Fire Safety Certificate is only for Guest Rooms.

1. Name & address of the building : M/s. Hotel Good Palace, 15A/63, WEA, Karol Bagh, New Delhi- 05.
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/SZ/2018/2333 dated 16.10.2018.
5. Fire Safety directives letter No : Nil
6. Date of inspection : 13.07.2021
7. Name of the Inspecting Officers : P.V. Rathee, ADO (Shankar Road)
8. Name and designation of officers from the building side : Sh. Gurvinder Singh (Owner)
9. Year of Construction : Before 2003
10. Applicant's letter No. : Online application id 2021062914407 dated 02.07.2021

The said guest house is comprised of basement, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Fire safety requirements as per FSC dt. 16.10.2018	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	Old Case	01	MR being old case
	• Basements	Old case	01	MR being old case
	b. Width of staircases	-	-	-
	• Upper Floors	Old case	1.20 mts	MR being old case
	• Basements	Old case	1.25 mts	MR being old case
	c. Protection of exits	-	-	-
	• Fire check door	Required	Not Provided	date of compliance has been extended up to 30.09.2021
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	1.50 mts	MR
	h. Door Size	Old case	0.80 mts	MR being old case
3	Compartmentation.			
	• Fire check door	Required	Not Provided	date of compliance has been extended up to 30.09.2021
	• Sealing of electrical shafts	N/A	Sealed	----
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Not Provided	date of compliance has been extended up to 30.09.2021
5	Fire Extinguishers			
	• Total numbers	14	Provided	MR
	• Types	CO ₂ , ABC, WCO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/359-374 dated 29.06.2021 in respect of existing building (copy enclosed) shall be implemented by 30.09 .2021 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/GH/SZ/2018/2333 dated 16.10.2018, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

[Handwritten Signature] 28/7/21

Signature of the Inspecting Officer
P.V. Rathee
Asstt. Div. Officer (SRD)

D.O. (S/W)

[Handwritten Signature]
29/07/2021

Dy. Ch. (S/W)

[Handwritten Signature]

A NOC RD,

P.T. Letter is put up for sign. please