

C-15

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/School/2021/ 567

Dated: 30/07/2021

FIRE SAFETY CERTIFICATE

Certified that the Building Mount Carmel School, Located at Bamnauli, Sector-28, Dwarka , New Delhi 110077 comprised of Basement + Ground + 3 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2017/SZ/674 Dated 11/05/2017 The premises was re inspected by the officers concerned of this department on 20/07/2021 in the presence of Mr. Thomas George (Admin officer) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Delhi Fire Service Act 2007 and Rules, 2010 and that the building/premises is fit for occupancy class-B "Educational" with effect from 30/7/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/7/21..... at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal Mount Carmel School , Bamnauli, Sector – 28, Dwarka , New Delhi 110077.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/A

INSPECTION REPORT

1. Name & address of the building: Mount Carmel School, Located at Bamnauli, Sector-28, Dwarka , New Delhi 110077
2. Type of Occupancy : Educational (Basement + Ground+ 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2017/SZ/674 Dated 11/05/2017
5. Fire Safety directives L. No. : **N/A**
6. Date of inspection : 20-07-2021
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
 from the building side : Sh. Thomas George (Admin officer)
9. Year of Construction : 2011-12
10. Applicant's letter No. : Email Dated 13/07/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement & As per N/5	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR (being old case)
	• Gate width	4.5 mtr	Provided	MR (being old case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	Provided	MR
	• Basements	2 Nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr each	153 cm & 149 cm including railing	MR (being old case)
	• Basements	1.5 mtr each	Provided	MR (being old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos.	02 Nos.	MR
	e. Width Of Corridor	1.5mtr	208cm Provided	MR
	f. Door Size	1.0 mtr	111 cm Provided	MR

N/10

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c charge	Exhaust fans provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	15 nos.	. Provided	MR
	• Types	ABC	ABC	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

21
4/11

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto starting/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm	Provided	MR
		30 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	Provided	MR
		NA	Provided	MR
		NA	Provided	MR
		15000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA

N/12

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2017/SZ/674 Dated 11/05/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

AD
20/07/21

Signature of the Inspecting Officer

Name Udai Vir Singh

Designation ADO/DWK

D0/SW

AD
26/07/2021

By CFO (SZ)

F.T.
AD/O (DWK)

Sir AT letter is put up for sign etc

Dyefolsz

[Signature]

AD
28/7

M.S. cell