

C-21

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/SZ/2021/ 562

Dated: 29/7/21


FIRE SAFETY CERTIFICATE

Certified that **Ramjas School located at Anand Parbat, New Delhi- 110005** having two wings namely Upper wing and Lower wing. Upper wing is comprised of Ground floor only and Lower wing is comprised of ground plus one upper floor, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2018/1616 dated 11.07.2018. The school building was re-inspected by the officer concerned of this department on 23.07.2021 in the presence of Sh. C.P Singh (Estate Officer) and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 29/7/21 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

O/C 

Copy to: -

1. The Principal, Ramjas School , Anand Parbat, New Delhi- 110005
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Ramjas School, Anand Parbat, New Delhi- 110005.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/SZ/2018/1616 dated 11.07.2018
5. Fire Safety directives letter No : Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011.
6. Date of inspection : 23.07.2021
7. Name of the Inspecting Officers : P.V. Rathee, Asstt. Div. Officer (SRD)
8. Name and designation of officers from the building side : Sh. C.P. Singh (Estate Officer)
9. Year of Construction : Before 1990
10. Applicant's letter No. : Online email id: chattarpal.s@ramjasap.edu.in dated 15.07.2021

The School building is having two wings namely- Upper wing and Lower wing. Upper wing is comprised of ground floor only and Lower wing is comprised of ground and first floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per circular of DoE dt. 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 mts 4.5 mts N/A	Provided Provided N/A	MR MR N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03 N/A	03 N/A	MR N/A
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.5 mts or less & 0.75 mt N/A	1.52, 1.30 & 1.08 mts. N/A	MR N/A
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	Old case	2.40 mts	MR
	h. Door Size	1.0 mts	Provide (1.0 mt)	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A ---- N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A Natural ventilation	N/A MR

	<ul style="list-style-type: none"> Total numbers Types IS marking 	25 nos. ABC type ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A 30 m 5 mm	Provided Provided Provided	---- ---- ----
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A D.G set (62.5 KVA) N/A	N/A N/A N/A ---- N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	----
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping 	--- N/A N/A N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A N/A N/A	----- N/A N/A N/A N/A N/A N/A N/A N/A

	<ul style="list-style-type: none"> • Terrace level 	----	-----	-----
	<ul style="list-style-type: none"> ➤ Discharge of pump 	N/A	180 LPM X 02 nos.	----
	<ul style="list-style-type: none"> ➤ Head of the pump 	N/A	30 mts each	----
	<ul style="list-style-type: none"> ➤ Power Supply 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	N/A	N/A	N/A
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Overhead Tank capacity 	N/A	5000 lts.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	Provided	----
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Location 	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/SZ/2018/1616 dated 11.07.2018, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

Accordingly, DFA is put up for approval & signature please.