

C-10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2021/SZ / 568

Dated: 30/7/21

FIRE SAFETY CERTIFICATE

Certified that the Sagar Convent School, 65-C, Deep Enclave Part-III, Vikas Nagar, New Delhi-110059, comprised of ground floor plus one upper floor, owned/occupied by Sagar Convent School. The School building was inspected by the officer concerned of this department on 15/07/2021 in the presence of Sh. Ganga Prasad and found that school building have complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....30/7/21..... at New Delhi.


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Chairman,
Sagar Convent School,
65-C, Deep Enclave Part-III, Vikas Nagar, New Delhi-110059.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Sagar Convent School, 65-C, Deep Enclave Part-III, Vikas Nagar, New Delhi-110059
2. Building is comprised of : Ground floor plus one upper floor
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC : N/A
6. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
7. Date of inspection : 15/07/2021
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Ganga Prasad
10. Year of Construction : Before 2016
11. Applicant's letter No. : Nil dated 01/06/2021

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirement | Provided at site | Remarks MR/NMR |
|--------|---|---|---|---------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road | Accessible 06 m 4.5 m N/A | 06 m Directly accessible from road N/A | MR MR N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floors • Basements | 02 no. N/A | 02 no. N/A | MR N/A |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> • Upper Floor • Basements | 1.50 & .75 m N/A | 1.50 & .95 m N/A | MR N/A |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> • Fire check door • Pressurization | N/A N/A | N/A N/A | N/A N/A |
| | d. No. of continuous staircases to terrace | N/A | N/A | N/A |
| | e. Width of Corridor | 1.50 m | 2.80 m | MR |
| | f. Door Size | 1.0 m | 1.0 m | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> • Basements • Upper floors | N/A Required | N/A Natural ventilation provided | N/A MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers • Types • IS marking | 06 no's ABC/CO ₂ type ISI marked | Provided Provided Provided | MR MR MR |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |


| | | | | |
|-----|--|-----------|-----|-----|
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | N/A | N/A | N/A |
| 12. | Yard Hydrants | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping | N/A | N/A | N/A |
| | <ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | N/A | N/A | N/A |
| 15. | Exit Signage. | N/A | N/A | N/A |
| 16. | Provision of Lifts. | (No Lift) | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area. | | | |
| | <ul style="list-style-type: none"> Total Area Location | N/A | N/A | N/A |

| | | | | |
|-----|---|-----|-----|-----|
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | N/A | N/A | N/A |


The building was issued shortcomings vide letter no. F6/DFS/MS/2017/2722 dated 18/10/2017 has been complied. The same were checked and found functional at the time of inspection. Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education it is recommended to grant Fire Safety Certificate.


 Signature of Inspecting Officer 19/7/2021
 Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)



20/07/2021
 Dy CPO (S2)

what is the width requirement of corridor



20/7


ADD (K P)

6m width of the corridor required to ISM. Resubmitted please


20/7/2021

Dy CPO (S2)


20/7

CFO.  NP

