

C-22

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/SZ/2021/ 566

Dated: 30/07/2021

FIRE SAFETY CERTIFICATE

Certified that the building **Sant Kirpal Model School** Located at, **Shiv Enclave, Dichaon kalan Road Najafgarh , New Delhi – 110043** owned/ occupied by Sant Kirpal Model School was granted NOC for Ground plus one upper floor by this department vide letter no. F.6/DFS/MS/School/2017/SZ/1266 Dated 24/08/2017. The premises was re inspected by the officer concerned of this department on 01/07/2021 in the presence of Sh. Neeraj Kaushik (Vice Principal) The Sant Kirpal Model School comprised of ground plus one upper floor of a three storied building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building / premises (**Ground plus one upper floor only**) is fit for the occupancy class "Educational" Group B with effect from 30/7/21 for a period of **three years** subject to compliance of the conditions printed as under.

Issued on 30/7/21 at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:-

1. The Principal, Sant Kirpal Model School Located at, Shiv enclave, Dichaon kalan road Najafgarh , New Delhi – 110043
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. The 2nd floor room shall not be used for school activities. The FSC shall be null & void if 2nd floor room is used for school.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. Basement shall be used as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/12

INSPECTION REPORT

1. Name & address of the building: Sant Kirpal Model School Located at, Shiv Enclave, Dichaon kalan Road Najafgarh , New Delhi – 110043.
2. Type of Occupancy : Educational (Ground + 01 Upper Floor) *the building comprised of G+2 UFs.*
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2017/SZ/1266 Dated 24/08/2017
5. Fire Safety directives Letter No. : NA
6. Date of inspection : 01/07/2021
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer from the building side : Sh. Neeraj Kaushik (Vice Principal)
9. Year of Construction : 1997 (GF & FF) & 2016-2017 (SF)
10. Applicant's letter No. : Email Dated 08/06/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR																											
1.	Access of building																														
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1"> <tr> <td>Accessible 06 mtrs</td> <td>05 mtr</td> <td>MR(Old case)</td> </tr> <tr> <td>4.5mtrs</td> <td>Directly accessible from road</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	Accessible 06 mtrs	05 mtr	MR(Old case)	4.5mtrs	Directly accessible from road	MR	NA	NA	NA																				
Accessible 06 mtrs	05 mtr	MR(Old case)																													
4.5mtrs	Directly accessible from road	MR																													
NA	NA	NA																													
2.	Number, width, Type & Arrangements of exits																														
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<table border="1"> <tr> <td>01 No's</td> <td>2 Nos.</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>150 cm/ additional staircase of 75 cm if less than 150 cm</td> <td>2 X 110cm</td> <td>MR (Old case)</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>Required</td> <td>01</td> <td>MR</td> </tr> <tr> <td>1.5 mt</td> <td>150 cms</td> <td>MR</td> </tr> <tr> <td>100 cm</td> <td>90 cm</td> <td>MR (Old case)</td> </tr> </table>	01 No's	2 Nos.	MR	NA	NA	NA	150 cm/ additional staircase of 75 cm if less than 150 cm	2 X 110cm	MR (Old case)	NA	NA	NA	NA	NA	NA	NA	NA	NA	Required	01	MR	1.5 mt	150 cms	MR	100 cm	90 cm	MR (Old case)		
01 No's	2 Nos.	MR																													
NA	NA	NA																													
150 cm/ additional staircase of 75 cm if less than 150 cm	2 X 110cm	MR (Old case)																													
NA	NA	NA																													
NA	NA	NA																													
NA	NA	NA																													
Required	01	MR																													
1.5 mt	150 cms	MR																													
100 cm	90 cm	MR (Old case)																													
3.	Compartmentation																														
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<table border="1"> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA														
NA	NA	NA																													
NA	NA	NA																													
NA	NA	NA																													
NA	NA	NA																													
NA	NA	NA																													

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		12 a/c per hour	Natural ventilation provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 Nos. ABC & CO ₂ ISI marked	10 nos. Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

11/14

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2017/SZ/1266 Dated 24/08/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ADDO/DWR

12/12/21
12/12/21
 by 12/12/21
 F.T. placed
ADDO/DWR

Sir AT letter is put up for by ple
12/12/21
12/12/21