

C-40

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 570

Dated: 30 / 7 / 2021

FIRE SAFETY CERTIFICATE

Certified that Sarvodaya Kanya Vidyalaya No- 2, Mehrauli, Main Bazar, New Delhi-110030 (1923079) comprised of Ground plus Three Upper floor have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concern of this department on 19/07/2021 in the presence of Smt. Seema Khetar Pal (Vice Principal) of the school and that the building/premises is fit for occupancy class "Educational, Group-B" (School) as above with effect from the date of issue of this certificate for period of Three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Issued on 30/7/2021 at New Delhi by


(ATUL GARG)
DIRECTOR
old

Copy to: -

1. The Principal, Sarvodaya Kanya Vidyalaya No- 2, Mehrauli, Main Bazar, New Delhi-110030 (1923079)
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

2/14

INSPECTION REPORT

1	Name & Address of the Building	Sarvodaya Kanya Vidyalaya No 2, Mehrauli, Main Bazar New Delhi -110030 (ID- 1923079)		
2	Type of Occupancy	Educational		
3	Building Comprised of	Ground plus three upper		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	19/03/2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Smt. Seema Khetar pal (Vice Principal)		
10	Year of construction	1964		
11	Applicant letter No.	Gmail Dated 12/07/2021		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> Accessible -NA- -NA- 	<ul style="list-style-type: none"> 6 mtr -NA- -NA- 	<ul style="list-style-type: none"> MR -NA- -NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor. 	<ul style="list-style-type: none"> Required -NA- 	<ul style="list-style-type: none"> 2 Nos -NA- 	<ul style="list-style-type: none"> MR -NA-
	b) Width of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor 	<ul style="list-style-type: none"> 1.5 m/ 0.75 m -NA- 	<ul style="list-style-type: none"> 1.50 mtr each -NA- 	<ul style="list-style-type: none"> MR -NA-
	c) Protection of exits			
	<ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization 	<ul style="list-style-type: none"> -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA-
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	NA	-NA-
	f) Door size	1 mtr	1 mtr.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	<ul style="list-style-type: none"> -NA- -NA- -NA- -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA- -NA- -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA- -NA- -NA- -NA-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	<ul style="list-style-type: none"> 30a/c per hour 12a/c per hour 	<ul style="list-style-type: none"> -NA- -NA- 	<ul style="list-style-type: none"> -NA- -NA-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	<ul style="list-style-type: none"> Required CO²&ABC ISI mark 	<ul style="list-style-type: none"> 30 Nos CO² & ABC Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	<ul style="list-style-type: none"> 02 30m 5m 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	-NA-	-NA-	-NA-

N/16

	<ul style="list-style-type: none"> Flow switch panel. PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 156 dated 26/03/2021

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.

Accordingly, DFA is put up for approval and signature please.

Signature

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)



DD/SO

Diry 20/07

DFO (G)

Recommended for F.S.C.

sh 22/7

E.F.O.

28/7

27/7/2021

Amu BTD

As approved, F-7. Letter is put up for your