

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2021/ 09

Dated: 02/08/2021

**FIRE SAFETY CERTIFICATE**

Certified that the building **Sky vision Welfare Society** Located at **Sector-9, Dwarka, New Delhi** comprised of (Basement + stilt/Ground + 6 Upper Floors) owned/ occupied by **Sky vision Welfare Society**, was issued FSC vide Letter No. F-6/DFS/MS/09/942 Dated 06/04/2009 (For G+05 UFs). The premises was Jointly inspected by the officers concerned of this department & DDA on 15/07/2021 and found that the said building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 and that the premises is fit for occupancy class B "Educational building" with effect from 02/08/2021 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/08/2021 at New Delhi by.

  
 (Atul Garg)  
 Director  
 Delhi Fire Service.

Copy to:

1. The Vice Chairman, DDA, INA Vikas Sadan, New Delhi-110023
2. Mr. Bhagwan Das (Admin Manager) Sky vision Welfare Society Located at Sector-9, Dwarka, New Delhi

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

INSPECTION REPORT

1. Name & address of the building: Skyvision Welfare Society. Located at Sector-9, Dwarka, New Delhi.
2. Type of Occupancy : Residential (Basement+ stilt/Ground + 6 upper floor)
3. Type of Case : **Completion ( F-13(221)2007/Bldg-OCC**
4. Details of previous NOC : **F-6/DFS/MD/09/942 Dated 06/04/2009 (Issued for**

**G+5Ups)**

5. Fire Safety directives L. No. : **F-6/DFS/MS/BP/2008/1721 Dated 25/06/2008**

**(for B+S/G=06 UFs)**

No. of Students=150
No. of class rooms=10
Plot area=2375sqf
Covered Area— sqm

6. Date of inspection : 15/07/2021

7. Name of the Inspecting Officer : Udai vir Singh, ADO (DWK)

8. Name and designation of Officer

from the building side : Joint Inspection along with Sh. Roshan Lal & Sh.

Shahrookh Ali ( JE DDA)

9. Year of Construction : 2008 - 2009

10. Applicant's letter No. : F-13/(221)2007/Bldg-OCC dated 22/03/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As Per Directive	Provided at site	Remarks MR/NMR
1.	Access of building			MR
	• Road width	12 Mtr	Provided	MR
	• Gate width	5 Mtr	5.30m	MR(old case)
	• Width of internal road	6 Mtrs	Provided ( Old case)	MR (Old Case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper floors	1.5 m & 1 m	Provided	MR(Old Case)
	• Basements	1.5 m & 1 m	Provided	MR(Old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 mtr	2.60m	MR
	f. Door Size	Required	Provided	MR(Old case)

N/10

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	Required	Open able window	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	18 nos.	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC & CO <sub>2</sub>	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	02	02	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	Required	NA	MR
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	One	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	02	Provided near each internal hydrant	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Required	Provided	MR

N/11

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	50000 ltrs	NA
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
		25,000 ltrs	Provided	MR
		Required	Provided	MR
15	Exit Signage			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	Required	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	DG Set 75 KVA	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	Required	Provided	MR
		5 <sup>th</sup> Floor	Old case	MR
19.	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

N/12

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F-6/DFS/MD/09/942 Dated 06/04/2009 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note :- 1. Original file of the premises could not be traced. The copies of FSC, approved plans & directives issued vide letter dated 25/06/2008 are received from JE (DDA)/ occupant are attached.

2. The FSC (Placed at C/16) issued for G+5 UFs however the directive issued for B+G/S+06 UFs.

3. Now the case is received for completion from DDA.

Signature of the Inspecting Officer  
 Name *Uday Vir Singh*  
 Designation *AO/DA*

Signature of the Inspecting Officer  
 Name  
 Designation

~~DO/SW~~ Completion case.

*23/07/2021*

*26/7*

*27/7*

*27/7*

*27/07/2021*

