

2-10

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**


No.F.6/DFS/MS/EH/2021/SZ/ 175

Dated: 9/8/21

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Kali Ghata Misthan Bhandar Pvt. Ltd. running at first floor only, a building comprised of ground (sweet shop), first floor (restaurant), second floor (vacant) located at F-146, Arya Samaj Road, Uttam Nagar, New Delhi-110059, owned/occupied by M/s Kali Ghata Misthan Bhandar Pvt. Ltd. have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 12/07/2021 in the presence of Sh. Navin Kumar Gupta and found that the building (first floor) is fit for occupancy 'Group D' Assembly Building (Restaurant) with effect from 9/8/21 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on..... 9/8/21 ..... at New Delhi by

  
(Atul Garg)  
**Director**  
Delhi Fire Officer  
22/8

To,

The Manager, M/s Kali Ghata Misthan Bhandar Pvt. Ltd,  
F-146, Arya Samaj Road, Uttam Nagar, New Delhi-110059.

Copy to:-

The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station,  
Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry

**INSPECTION REPORT**

1. Name & address of the building : M/s Kali Ghata Misthan Bhandar Pvt. Ltd. F-146, First Floor, Arya Samaj Road, Uttam Nagar, New Delhi-59.
2. Building is comprised of : G+2 upper floor but Restaurant is running at first floor only
3. Type of Occupancy : Assembly
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 12/07/2021
8. Name of the Inspecting Officers: : R.K. Yadav (ADO)
9. Name of the designation of Officer from the building side : Sh. Navin Kumar Gupta
10. Year of Construction : 1995
11. Applicant's letter No : ID No. 2021041312872 dated 08/07/21

S.No	Minimum Standards on fire safety requirements	NBC/UBBL 2005 & 1983	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	06 m	Provided	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	2 no.	Provided	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m & 1 m	1.5 & 1.0 M	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	Required	Provided	MR
g. Width of Corridor	N.A.	N.A.	N.A.	
h. No. of door	2 no.	2 no.	MR	
i. Door Size	2 m & 1.5 M	2 M each	MR	
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Provided	MR

5.	Fire Extinguisher			
	Total numbers	06 no.	06 no.	MR
	types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A.	N.A.
	Location of main panel	N.A	N.A.	N.A.
	Location of repeater panel	N.A	N.A.	N.A.
	Alternate source of power	N.A	N.A.	N.A.
	Hooters	N.A	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A	N.A.	N.A.
	upper floor	N.A	N.A.	N.A.
	sprinkler above false ceiling	N.A	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants each floor	1 no.	1 no.	MR
	Hose box each floor	1 no.	1 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	• Ground Level	N.A	N.A	N.A
	• Discharge of main Pump	N.A	N.A	N.A
	• Head of Main Pump	N.A	N.A	N.A
	• Number of main pumps	N.A	N.A	N.A
	• Jockey pump out put	N.A	N.A	N.A
	• Jockey pump head	N.A	N.A	N.A
	• Standby pump out put	N.A	N.A	N.A
	• Standby pump Head	N.A	N.A	N.A
	• Auto Starting /Manual stopping	N.A	N.A	N.A
	• Pump House Access	N.A	N.A	N.A
	• Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the Pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	20,000 Liters	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A.	N.A.
	Pressurization of Lift lobby	N.A	N.A.	N.A.
	Communication in lift car	N.A	N.A.	N.A.
	Firemen's grounding switch	N.A	N.A.	N.A.
	Lift Signage	N.A	N.A.	N.A.
17	Standby power supply	N.A	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A	N.A.	N.A.
	Flow switch panel	N.A	N.A.	N.A.
	PA system panel	N.A	N.A.	N.A.
	Batter backup	N.A	N.A.	N.A.
	Building Floor Plans	N.A	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A.	N.A.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

The total covered area of the eating house at FF is 167 sq. meters. As per Part-IV, NBC-2016, Total the number of seats will come Approx. 93 ( $167 / 1.8 = 92.77$ ) for the restaurant.

Signature of the Inspecting Officer

Name :-R.K.Yadav

Designation :-ADO(JKP)

DO (South West)

23/07/2021