

C-32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2021/WZ/School/ 579

Dated: 3/8/21

FIRE SAFETY CERTIFICATE

Certified that the P.K. Model School, Plot No.117 to 119, Kailash Vihar, Kirari, Suleman Nagar, Delhi- 110086, running on ground & 1st floor only in a building comprised of ground + two upper floors owned/occupied by P.K. Model School has already been issued FSC by this department vide letter No. F.6/DFS/MS/School/2017/WZ/526 dated 11.04.2017. The premises was re-inspected by the officer concerned of this department on 23.07.2021 in the presence of Sh. Praveen (Principal) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with circular issued by Director of Education, GNCT of Delhi vide letter No.262-362 dated 17.01.2005 and found the building/premises is fit for occupancy class Educational (Group-B) with effect from 3/8/21 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 3.8.21..... at New Delhi by

(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

[Handwritten signature and date 3/8/2021]
[Handwritten initials and date 02/8/2021]

Copy to :-

1. The Principal, P.K. Model School, Plot No.117 to 119, Kailash Vihar, Kirari, Suleman Nagar, Delhi- 110086.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K'[sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
5. This fire safety certificate may not in any way be treated as regularization. (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of Rule 37] along with a copy of this Certificate, six months prior to its expiry."

http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : P.K. Model School, Plot No.117 to 119, Kailash Vihar, Kirari, Suleman Nagar, Delhi- 110086.
2. Type of Occupancy : Educational (School running Gr.+1 floor of Gr. + 02 upper floor building)
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2017/WZ/526 dated 11.04.2017
5. Fire Safety directives letter No : DOE Circular dated 01.03.2011/ NBC Part-IV
6. Date of inspection : 23.07.2011
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Praveen (Principal)
9. Year of Construction : 1994 & 2015
10. Applicant's letter No. : Online e-mail dated 11.02.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir.1.3.11 NBC Part-IV	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	1.3 & 1.12m	MR (Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	04nos.	06nos.	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

	• Alternate source of power	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	220lpm	220lpm	MR
	➤ Head of the pump	40m	40m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA
-----	---	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/School/2017/WZ/526 dated 11.04.2017 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
26/7/21

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

~~DO (NW)~~

Ajay
27/07/2021
~~DO (NW)~~

[Signature]
27/7/2021

~~ADO Rohini~~

Sir F.T is put up for your perusal & signature pls.

~~DO (NW)~~
[Signature]
27/8/2021

[Signature]
02/08/2021

rest all