

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001


No. F.6/DFS/MS/Club/2021/NDZ/ 37.7

Dated: 05/08/2021

FIRE SAFETY CERTIFICATE

Certified that the East End Club at FC-13, CBD Ground, Karkardooma Court Road, Shahdara, Delhi-110032, comprised of basement, ground plus two upper floors owned/occupied by East End Club was issued FSC vide letter No. F6/DFS/MS/Club/2018/NDZ/1654 dated 16/07/2018. The premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 29/07/2021 in the presence of Sh. Rajesh Mittal, Manager and that the building is fit for occupancy Group D-6 "Eating House)" with effect from05/08/2021 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on.....05/08/2021.....at New Delhi by


(Dr. S. K. Tomar)
Dy. Chief Fire Officer

To,

The Manager,
East End Club,
FC-13, CBD Ground,
Karkardooma Court Road,
Shahdara, Delhi-110032

Copy to:-

The Assistant Commissioner (Excise),
Office of The Commissioner Excise, Entt. & Luxury Tax,
L-Block, Vikas Bhawan, I.P. Estate, New Delhi

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : East End Club FC-13 at CBD Ground, Karkardooma Court Road, Delhi-110032
2. Building is comprised of : B+G+Two upper floors
3. Type of Occupancy : Assembly (Eating House)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/Club/2018/NDZ/1654 dated-16/07/2018
6. Fire Safety direction letter No. : Old Requirements
7. Date of Inspection : 29/07/2021
8. Name of the Inspecting officers : ADO Nagender Singh
9. Name and designation of Officer from the building side : Sh. Rajesh Mittal, Manager
10. Year of Construction : 2002
11. Applicant's email ID : manager_eec06@yahoo.com dt- 19/07/2021


Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	6 m	45 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	2 nos.	2 nos.	MR
	• Basement	2 nos.	2 nos.	MR
	B. Width of Staircases			
	• Upper floor	1.5 m	1.8 m & 1 m	MR(accepted earlier)
	• Basement	1.5 m	1.7 m & 0.85 m	MR(accepted earlier)
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	1 no.	1 no.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2 m	2 m	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Ventilated	Ventilated	MR
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	08 nos.	08 nos.	MR
	• Types	ABC /CO ₂	ABC/ CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

First Aid Hose Reels:				
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	40 m	40 m	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
	•			
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	15,000 Ltrs.	15,000 Ltrs.	MR
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to renew FSC under rule 37 of Delhi Fire Service Rules, 2010.


(Nagender Singh)
ADO (Shahdara)


Dy. CFO (NDZ)

F.T. pl.


2/8/21

ADO (Shahdara)

FT letter is placed for signatures please


2/8/21

Dy CFO (NDZ)


4/8/21

FD Section

