

G-19

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 580

Dated: 04/08/2021

FIRE SAFETY CERTIFICATE

Certified that the Building **Sir Chhotu Ram Public School** Located at **WZ-727-A, Sir Chhotu Ram Marg, Palam Village New Delhi-110045** the school building having Two blocks, both are interconnected & comprised of **Ground + One Upper Floor** was issued Fire Safety Certificate by this department vide Letter no. F6//DFS/MS/School/2018/SZ/588 Dated 05/04/2018. The premises was re inspected by the officer concerned of this department on 07/07/2021 in the presence of Smt. Kanta Solanki (Manager). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of **three years**, subject to compliance of the condition given below.

Issued on . 04/08/2021 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Principal, Sir Chhotu Ram Public School Located at WZ-727-A Sir Chhotu Ram Marg, Palam Village New Delhi-110045.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. **The Adm Block comprising of Ground + 01 Upper Floor shall not be used for school activities.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per building bye laws.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N19
INSPECTION REPORT

1. Name & address of the building: Sir Chhotu Ram Public School Located at WZ-727-A, Sir Chhotu Ram Marg, Palam Village New Delhi-110045
2. Type of Occupancy : Educational Two Blocks (Ground +One Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/588 Dated 05/04/2018
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 07/07/2021
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building sid :Smt. Kanta Solanki (Manager)
9. Year of Construction : 2003&2004
10. Applicant's letter No. :Email dated 01/07/2021

No. of Students=268
No. of class rooms=20
Plot area=8562.50sqft
Covered area=7035sqft

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement as per FSC dt. 05/04/2018 as per N/6	Provided at site	Remarks MR/NMR																								
1.	Access of building																											
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1"> <tr> <td>Accessible</td> <td>Provided for small fire unit</td> <td>MR(Old Case)</td> </tr> <tr> <td>4.5 mtr</td> <td>Direct accessible from road</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	Accessible	Provided for small fire unit	MR(Old Case)	4.5 mtr	Direct accessible from road	MR	NA	NA	NA																	
Accessible	Provided for small fire unit	MR(Old Case)																										
4.5 mtr	Direct accessible from road	MR																										
NA	NA	NA																										
2.	Number, width, Type & Arrangements of exits																											
	<ul style="list-style-type: none"> a. Number of staircases • Upper floors • Basements b. Width of staircases • Upper floors • Basements c. Protection of exits • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	<table border="1"> <tr> <td>2</td> <td>2nos</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>1.5m</td> <td>School BL=1.5m,1.4m (including railing) Adm BL=116cm</td> <td>MR(Old Case)</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>150cm</td> <td>155cm,175cm</td> <td>MR Old Case</td> </tr> <tr> <td>100cm</td> <td>90cm (Old Case)</td> <td>MR old case</td> </tr> </table>	2	2nos	MR	NA	NA	NA	1.5m	School BL=1.5m,1.4m (including railing) Adm BL=116cm	MR(Old Case)	NA	NA	NA	NA	NA	NA	NA	NA	NA	150cm	155cm,175cm	MR Old Case	100cm	90cm (Old Case)	MR old case		
2	2nos	MR																										
NA	NA	NA																										
1.5m	School BL=1.5m,1.4m (including railing) Adm BL=116cm	MR(Old Case)																										
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										
150cm	155cm,175cm	MR Old Case																										
100cm	90cm (Old Case)	MR old case																										
3.	Compartmentation																											
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<table border="1"> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA											
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										
NA	NA	NA																										

n/10

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation Provided	MR
5.	Fire Extinguishers			
	• Total numbers	07nos.	07 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
	Pumping Arrangements			
13	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

N/11

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter : F6/DFS/MS/School/2018/SZ/588 Dated 05/04/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note :- One another block comprised of Ground plus one upper floor is also seen in the premises. The same shall not be used for school activities.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *AD/DC*

14/07/21
AD/DC
14/07/21
AD/DC
AD/DC