

C-28

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No.F6/DFS/MS/School/2021/ 590

Dated: 9/08/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Building Vandana Kindergaten School owned/occupied by Krishna geetanjali foundation society (Regd.) Located at Sector – 10, Phase – 1, Dwarka, New Delhi – 110075 comprised of Basement + Stilt/ Ground + 3 Upper Floor was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/1930 Dated 21/08/2018. The premises was re inspected by the officers concerned of this department on 24-07-2021 in the presence of Sh. Harsh Tondon (Director) and found that the said building have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 under DFS Act 2007 and that the premises is fit for occupancy class-B “Educational” with effect from 9/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....9/8/21..... at New Delhi by.

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer  
Delhi Fire Service.

Copy to:

1. The Principal Vandana Kindergaten School owned/occupied by Krishna geetanjali foundation society (Regd.) Located at Sector – 10, Phase – 1, Dwarka, New Delhi – 110075
2. Directorate of Education Old Secretariat Delhi – 110054

**Following fire safety directives must be adhered to:-**

- 1 **The passage lead to stairs shall be kept free from any obstruction.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/119  
**INSPECTION REPORT**

1. Name & address of the building: Vandana Kindergarten School run by Krishna geetanjali foundation society (Regd.) Located at Sector – 10, Phase – 1, Dwarka, New Delhi – 110075.
2. Type of Occupancy : Educational (Basement + Stilt / Ground+ 3 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/1930 Dated 21/08/2018
5. Fire Safety directives Letter No. : F-16/Estate/CC/Fire Safety/2011/3298-3398, Dated 01/03/2011
6. Date of inspection : 24-07-2021
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Harsh Tondon (Director)
9. Year of Construction : 2011-2012
10. Applicant's letter No. : Email Dated 20/07/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/9	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR (being old case)
	• Gate width	4.5 mtr	Provided	MR (being old case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr & 0.75 m	1.51 & 0.90 mtr	MR (being old case)
	• Basements	1.5 mtr & 0.75 mtr	1.60 & 1.23 mtr (Including railing)	MR (being old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	01 Nos	MR
	e. Width Of Corridor	1.5m	1.50 mtr to 2.35 mtr	MR
	f. Door Size	01 mtr	1.05 mtr to 1.10 mtr	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Exhaust fans provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	18 nos.	18 Nos. Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	ISI marked	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	NA	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	100 mm	100 mm	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	01	Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	NA	NA	NA



N/15

20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2, Fire extinguisher provided near electric panel	MR
-----	--	----------	---	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F6/DFS/MS/School/2018/SZ/1930 Dated 21/08/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*Signature*  
28/07/21

Signature of the Inspecting Officer  
Name Sh. Udai Vir Singh  
Designation ADO/DWK

*DO/SCW*  
28/07/2021

*By order of P. L. S. ...*

*A DO (DWK) ...*

*F.t. ...*  
*ADP (DWK)*

*Sir AP letter is put up for ...*

*Signature*

*Signature*

*Signature*