

e-93

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2021/282

Dated : 04/08/2021

FIRE SAFETY CERTIFICATE

Certified that the **Ashwani Lodge Guest House** located at **8696-99, D.B.G. Road, Pahar Ganj, New Delhi** comprised of Basement + Ground + 04 Upper floors, Basement (Storage), Ground floor (02 guest rooms + reception), 1st floor to 3rd floor (04 guest rooms + 01 store room at each floor) and 4th floor (01 guest room + 01 manager room + 01 staff room), total 15 guest rooms owned/occupied by Ashwani Lodge Guest House was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/2018/NDZ/1112 dated 16/05/18. Now, The premises was re-inspected by the officer concerned of this department on 26/07/21 in the presence of Sh. Ashwani Gupta and found that the said guest house building **having fourth floor not in use as per affidavit dated 26.09.2019** has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1** Ground floor (001 office & 01 store room + reception), 1st floor to 3rd floor (04 guest rooms + 01 store room at each floor) total - **12 guest rooms up to third floor only** with effect from ~~04/08/2021~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~04/08/2021~~ at New Delhi by.


3/8/21

(Dr. S.K Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID No 2021052113495 dated 21.05.2021.
2. The Manager,
Ashwani Lodge Guest House at 8696-99, D.B.G. Road, Pahar Ganj, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building Ashwani Lodge Guest House at 8696-99, D.B.G. Road, Pahar Ganj, New Delhi
2. Type of occupancy:- Residential, Sub Division-A-1
B + Gr. + 04 Upper floors (total 12 Guest rooms) Basement (Storage), Ground floor (01 office & 01 staff room & reception), 1st floor to 3rd floor (04 guest rooms + 01 store room at each floor) and 4th floor not in use as per affidavit dated 26.09.2019
3. Type of case:- Renewal
4. Details of previous FSC:- No. F6/DFS/MS/EH/2018/NDZ/1112 dated 16/05/18.
5. Fire safety directives No.- N/A
6. Date of inspection:- 26/07/21
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal (DO /CD)
8. Name & designation of officer from the building side:- Sh. Ashwani gupta
9. Year of construction:- 1983
10. Applicant's letter No ID No 2021052113495 dated 21.05.2021

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	18 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	01 Nos.	01 Nos.	MR
	B. Width of staircase			
	1. Upper floors	0.80 mtr.	1.35 mtr.	MR
	2. Basements	0.80 mtr.	0.80 mtr.	MR
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	Exhaust fan	MR
	2) Upper floors	12 ACPH	Natural	MR

M

4/132

5.	Fire Extinguishers			
	1) Total numbers	12 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors Co type	Required	Provided	MR
	2) Location of main panel	Ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Ground floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 LPM	225 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

11/33

14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5000 ltr.	5000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/EH/2018/NDZ/1112 dated 16/05/18 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended up to third floor only.

Signature of the inspecting officer

Signature of the Inspecting Officer

[Handwritten Signature]
30/7/21

[Handwritten Signature]
30/7/21

Name: - Rajinder Atwal
Designation: - DO (CD)

Name: Ravinder Singh
Designation: ADO (CC)



[Handwritten Signature]
Dy. C.F.O. (NDZ)
[Handwritten Signature]
30/7/21

[Handwritten Signature]
A.D.O. (CC)
As approved for a part up for (CD) period
and signatur pl.