

C-55

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/School/WZ/2021/ 585

Dated: 5/8/2021

FIRE SAFETY CERTIFICATE

Certified that the **Rukmini Devi Bal Vatika (Junior Wing)**, Located at **GD-Block, Pitampura, Delhi-110034**, comprised of Basement + Ground + 03 Upper Floors was issued FSC by this department Vide Letter No. F6/DFS/MS/SCHOOL/2017/1554 Dated 03-07-2018. The said premise was re- inspected by the officer concerned of this department on 26.07.2021 in the presence of Sh. Partap Singh (Estate Officer), and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rule, 2010 and found that the premises/building is fit for occupancy class "Educational" Group B with effect from 5/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on5/8/21..... at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to: -

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Rukmini Devi Public School, GD-Block, Pitampura, Delhi-110034.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time. It should not bolted /locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any loss of life any property due to the non-functional of any fire safety measures, management shall be held responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
9. The Basement shall be used as per BBL.

INSPECTION REPORT

1. Name & address of the building: **Rukmini Devi Bal Vatika (Junior Wing), GD Block, Pitampura, Delhi – 110034.**
2. Type of Occupancy : Educational (Basement + Ground + 03 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC: F6/DFS/MS/SCHOOL/2018/1554 Dated 03.07.2018
5. Fire Safety directives Letter No. : NBC Part-4
6. Date of inspection : 26.07.2021
7. Name of the Inspecting Officer : S.P. Bhardwaj ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Partap Singh (Estate Officer)
9. Year of Construction : 2008
10. Applicant's letter No. : email dated 12.07.2021

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Part – 4 Requirements/letter dated 03.07.2018	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 m	3.50 m	MR (Old Case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper floors	1.5m	1.42 m & 90 cm	MR(Old Case)
	• Basements	1.5m	1.45 m & 76 cm	MR (Old Case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door		NA	NA
	• Sealing of electrical shafts		NA	NA
	• Fire Rating of shaft door		NA	NA
	• Water Curtain		NA	NA
	• Fire Dampers		NA	NA



4.	Smoke managements System			
	• Basements	30 a/c per hour	Exhaust Fans	MR
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	08 nos.	09 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	Required	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm & 180 lpm	Provided	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

N/24

14.	Captive water Storage for firefighting:		
	• Underground tank capacity	NA	NA
	➤ Draw off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	15,000Ltr	NA
15.	Exit Signage	Required	Provided
16.	Provision of Lifts		MR
	➤ Pressurization of Lift Shaft	NA	NA
	➤ Pressurization of lift lobby	NA	NA
	➤ Communication in lift Car	NA	NA
	➤ Fireman's Grounding Switch	NA	NA
	➤ Lift Signage	NA	NA
17.	Standby power supply	NA	NA
18.	Refuge Area		
	➤ Total area	NA	NA
	➤ Location	NA	NA
19.	Fire control room		
	➤ Detector system panel	NA	NA
	➤ Flow Switch Panel	NA	NA
	➤ PA System Panel	NA	NA
	➤ Battery backup	NA	NA
	➤ Building Floor Plans	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.
 In view of the deemed compliance of minimum standards of fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/SCHOOL/2018/1554 Dated 03.07.2018 is recommended, under rule 37 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

S.P. Bhardwaj, ADO (WP)
[Signature] 28/7/21

~~DO/Went~~

[Signature]
 28/7
[Signature]
 30/7/2021

~~DCFO (WL)~~

D.O. (WEST)/170
 DATED. 28/07/21

~~AAO/WP~~

It is sent up for sanction per

~~Defor WR~~

[Signature]