

C-24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2021/ 584

Dated:- 5/08/2021

**FIRE SAFETY CERTIFICATE**

Certified that the **Rajkiya Sarvodaya Kanya Vidyalaya No.2 at Shakarpur, Delhi-92** comprised of **Ground + 01 Upper floor**, owned/occupied by **Rajkiya Sarvodaya Kanya Vidyalaya**, was granted FSC by this department vide letter No. **F6/DFS/MS/School/2018/NDZ/1920 dated 20/08/2018**. The premises was re-inspected by the officer concerned of this department on 29/07/2021 in the presence of the Mrs. Daya parkash (HOS) & Sh. Vinod Khurana (Manager) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with **Circular No. F.16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/2011** issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building" Sub-Div. (B-I) Gr. + 1 upper floor only**, with effect from -----57.8.2021 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on .....57.8.21..... at New Delhi by.

  
4/8/21

(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education,  
D-Block, Anand Vihar, Delhi-91.
2. The Principal,  
Rajkiya Sarvodaya Kanya Vidyalaya No.2 at Shakarpur, Delhi-92.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".



**INSPECTION REPORT**

- |  |   |
|--|---|
| 1. Name & address of the building                            | Rajkiya Sarvodaya Kanya Vidyalaya No.2<br>at Shakarpur, Delhi-92              |
| 2. Type of occupancy:-                                       | Educational Group-B<br>Ground + 01 Upper floor                                |
| 3. Type of case:-  | Renewal   |
| 4. Details of previous FSC:-                                 | F6/DFS/MS/School/2018/NDZ/1920 dated<br>20/08/2018                            |
| 5. Fire safety directives No.-                               | Circular no. F.16/Estate/CC/FireSafety/2011/<br>3298 to 3398 dated 01/03/2011 |
| 6. Date of inspection:-                                      | 29/07/21  |
| 7. Name of the inspecting officer:-                          | Sh. Manoj Kumar Sharma (ADO/LN)   |
| 8. Name & designation of officer<br>From the building side:- | Mrs. Daya parkash (HOS) & Sh. Vinod<br>Khurana (Manager)                      |
| 9. Year of construction:-                                    | 2011-12   |
| 10. Applicant's letter No:-                                  | letter no. 226 dt. 22/07/2021 & email dated<br>23/07/2021                     |

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Old Circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	20 mtr.	MR
	2) Gate width	4.5 mtr.	4.5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	Upper floors	06 nos.	06 nos.	MR
	• A-Block G+1	2 nos.	2nos.	MR
	• B-Block G+1	1 No.	1 No.	MR
	• C-Block Gr. only	N/A	N/A	N/A
	• D-Block G+1	1 No.	1 No.	MR
	• E-Block G+1	2 Nos.	2 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 m	1.5 m each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 nos.	01 nos.	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	MR
	F. Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A



5.	Fire Extinguishers			
	1) Total numbers	12 Nos.	15 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A



	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/ School/2018/NDZ/1920 dated 20/08/2018, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

*Musho*  
20/12

Name :- M.K. Sharma  
Designation :- ADO (LN)



*F.G.P.*  
Dy. CFO/NDZ  
*Q. Kumar*  
30/7/21

*ADOC/NJ*  
F.T. letter is put up for org. pt

*Musho*  
20/12  
Dy CFO (NDZ)  
*Q. Kumar*  
4/8/21