

C-17

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No F 6/DFS/MS/2021/School/WZ / 594

Dated: 10 / 8 / 2021

FIRE SAFETY CERTIFICATE

Certified that the Govt. Sarvodaya Co-ed, Sr. Sec School, C-Block, Mangol Puri, Delhi-110083 comprised of 04 Blocks, Ground + One upper floor owned/occupied by Govt. Sarvodaya Co-ed, Sr. Sec School was granted FSC by this department vide letter No. F.6/DFS/MS/School/2018/WZ/1200 dated 23.05.2018. The premises was re-inspected by the officer concerned of this department on 28.07.2021 in the presence Mrs. Sushma Solanki (HOS) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/premise is fit for occupancy Group B Educational with effect from 10/8/21..... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on10/8/21..... at New Delhi

(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

dc
any

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Govt. Sarvodaya Co-ed, Sr. Sec School, C-Block, Mangol Puri, Delhi-110083

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Co-ed, Sr. Sec School, C-Block, Mangol Puri, Delhi-110083
2. Type of Occupancy : Educational
3. Type of Case : Renewal **04 Blocks (Ground + 01 upper floors)**
4. Details of Previous NOC : F.6/DFS/MS/School/2018/WZ/1200 dated 23.05.2018
5. Fire Safety directives letter No : Director of Education Circular Dated 01.03.2011
6. Date of inspection : 28.07.2021
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Sushma Solanki (HOS)
9. Year of Construction : 1999 & 2008
10. Applicant's letter No. : Online e-mail dated 14.06.2021

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Cir. Director of Education	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	--	--	--
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	08	A blk-2+1, B blk-2 C blk-2, D blk-1, (A blk & D blk are interconnected)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.5m	A & D blk-1.70m, 1.48 & 1.40m B blk-1.5 & 1.48m C blk-2 x 1.44m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m x 2	1 m x 2	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	14 nos.	14 nos.	MR
	• Types	ABC/CO2	ABC-14	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			


	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	NA	NA	NA
		NA	NA	NA
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel 	NA	NA	NA

N/13

	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/School/2018/WZ/1200 dated 23.05.2018 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.




Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

~~DO (NW)~~




02/08/2021
Aycho (wz)




08/08/2021

~~ADAR Rohini~~


FT letter is put up for kind
perusal and signature please.



DyFO (wz)



09/08/2021



06/08/21

ms/cell