

C-58

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6/DFS/MS/2021/School/WZ/ 597

Dated: 10/8/2021

FIRE SAFETY CERTIFICATE

Certified that the **Kendriya Vidyalaya Sector-8, Rohini, Delhi -85**, comprised of **Ground + Two upper floors** owned/occupied by **Govt. Co-Ed Sec School** was granted FSC by this department vide letter No. **F-6/DFS/MS/School/2015/1470/Dated 13/08/2015**. The premises was re-inspected by the officer concerned of this department on **28.07.2021** in the presence of **Sh. Uttam Kumar (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ...**10/8/21**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ...**10/8/21**..... at New Delhi


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel:-01123414250

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Kendriya Vidyalaya Sector-8, Rohini, Delhi -85.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : Kendriya Vidyalaya Sector-8 Rohini, Delhi -85
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**One Block Ground Plus Two Upper Floor**)
4. Details of previous NOC : F-6/DFS/MS/School/2015/1470/Dated 13/08/2015
5. Fire Safety directives letter No : DOE Circular dated 1.03.2011
6. Date of inspection : 28.07.2021
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers from the building side : Sh. Uttam Kumar (Principal)
9. Year of Construction : 1997
10. Applicant's letter No. : Online e-mail dated 29.06.2021

	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC/Rule 35 Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Required	12m	M/R
	• Gate width	Required	6 m	M/R
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	04	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases	--	--	--
	• Upper Floors	1.50 m	1.60 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	03	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	NA	NA	NA
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour 12 a/c per hour	N/A	N/A
	• Upper floors		Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	32 No's ABC/Co2 ISI marked	34 No's	M/R
	• Types		ABC-34	M/R
	• IS marking		Yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01		

	<ul style="list-style-type: none"> • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	Provided Provided	MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA			
9	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 ltr	Provided	MR
15	Exit Signage.			
		N/A	N/A	N/A
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 	N/A	N/A	N/A
		N/A	N/A	N/A

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F-6/DFS/MS/School/2015/1470/Dated 13/08/2015 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay
29/7

Signature of the Inspecting Officer
Name : Ajay Kumar Sharma
Designation: ADO (Rohini)

DO (NW)

Ajay
02/08/2021
By C/O (W2)

[Signature]
31/8/2021

~~ADO~~ Rohini

FT letter is put up for kind perusal and signature please. |

~~DCFO (W2)~~

[Signature]
9/8/2021

Ajay
6/8/21

ms/alf