

c-6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No.F.6 DFS/MS/School/2021/SZ/ 601

Dated: 12 / 8 / 2021

**FIRE SAFETY CERTIFICATE**

Certified that Sweet William Nursery School, at 25<sup>th</sup> Battalion, (Sashastra Seema Bal), Ghitorni, New Delhi -110047, comprised of ground floor owner / occupied by Sashastra Seema Bal, have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and verified by officer concern of this department on 30/07/2021 in the presence of Mr. Girdhary Lal Dagur, (Dy. Commandant) and that the premises is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12 / 8 / 2021 at New Delhi by

  
(ATUL GARG)  
DIRECTOR

Copy to: -

1. Mr. Girdhary Lal Dagur, (Dy. Commandant), Sweet William Nursery School, at 25<sup>th</sup> Battalion, (SASHASTRA SEEMA BAL), Ghitorni, New Delhi -110047.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/11

### INSPECTION REPORT

1	Name & Address of the Building	Sweet William Nursery School, at 25 <sup>th</sup> Battalion, (Sashastra Seema Bal), Ghitorni, New Delhi -110047		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground Floor only		
4	Type of Case	Nil		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	30-07-2021		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Girdhary Lal Dagur, (Dy. Commandant)		
10	Year of construction	----		
11	Applicant letter No.	Gmail Dated 20/07/2021		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>DOE circular Requirement</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>9 mtr</li> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>-NA-</li> <li>-NA-</li> </ul>
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>➤ Upper floors.</li> <li>➤ Basement floor.</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>
	<b>b) Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>➤ Upper floors</li> <li>➤ Basement floor</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>
	<b>c) Protection of exits</b>			
	<ul style="list-style-type: none"> <li>➤ Fire check door</li> <li>➤ Pressurization</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>
	<b>d) No. of continuous staircase to terrace</b>	-NA-	-NA-	-NA-
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1 m	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door.</li> <li>• Sealing of electrical shafts.</li> <li>• Fire rating of shaft door.</li> <li>• Water curtain</li> <li>• Fire dampers.</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> </ul>
<b>4.</b>	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> </ul>
<b>5.</b>	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI Marking</li> </ul>	<ul style="list-style-type: none"> <li>08 Required</li> <li>ABC</li> <li>ISI mark</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>ABC Type</li> <li>Provided</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>MR</li> </ul>
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> <li>• Length of hose-reel hose.</li> <li>• Nozzle Diameter</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> </ul>	<ul style="list-style-type: none"> <li>-NA-</li> <li>-NA-</li> <li>-NA-</li> </ul>
<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	-NA-	-NA-	-NA-

N/2

	<ul style="list-style-type: none"> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>	-NA-	-NA-	-NA-
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	-NA-	-NA-	-NA-
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting / Manual Stopping.</li> <li>Pump house access.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	-NA-	-NA-	-NA-
14.	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18.	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>Detector system panel.</li> <li>Flow switch panel.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

	<ul style="list-style-type: none"> <li>PA system panel.</li> <li>Battery backup.</li> <li>Building floor plan.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

*Signature*  
3/8/2024

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

~~DO (SD)~~

*dir*  
08/08/24

~~DeFO(S2)~~

*Sh*  
6/8

~~C.F.O.~~

*Sh*  
6/8



~~*dir*~~  
*9/8/24*

~~*Adm / BCP*~~

As approved, f.t. letter is put up for your signature pl

*Signature*  
11/8

1/26  
11/8