

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/CNG/2021/NDZ/ 388

Dated: 13/08/2021

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station (IGL) at CBD Shahdara, Delhi, comprised of ground floor only owned/occupied by Indraprastha Gas Limited was issued FSC vide letter No. F.6/DFS/MS/CNG/NDZ/2018/1694 dated 19/07/2018. The premises have complied with the fire prevention and fire safety requirements in accordance with the earlier directives issued vide letter no. F.5(3A)/DFS/CNG/2000/312 dated 31/07/2000 and verified by the officer concerned of Fire Service on 20/07/2021 in the presence of Sh. Bimal Kumar Karan, Manager and that the CNG Station is fit for occupancy class "Storage" (CNG Pump) with effect from 13/08/2021.... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed overleaf.

Issued on..... 13/08/2021 at New Delhi by



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



To,

The Chief General Manager (Fire & Safety),
IGL Bhawan, Plot No. 04, Community Center,
R.K. Puram Sector-09, New Delhi-110022

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
In premises "No Smoking" signs board both in Hindi and English shall be displayed in such a manner as to be easily readable by all people.
9. All comments/directions of the Chief Inspector of Explosives should always be permitted and followed.

N/10

INSPECTION REPORT

1. Name & address of the building : CNG Station at CBD Shahdara, Delhi
 2. Building is comprised of : Ground Floor
 3. Type of Occupancy : CNG Storage & Dispensing Unit
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F.6/DFS/MS/CNG/NDZ/2018/1694
 dated-19/07/2018
 6. Fire Safety direction letter No : F.5(3A)/DFS/CNG/2000/312 dt-31/07/2000
 7. Date of Inspection : 20/07/2021
 8. Name of the Inspecting officers : ADO Nagender Singh
 9. Name and designation of Officer
 from the building side : Sh. Bimal Kumar Karan, Manager
 10. Year of Construction : 2005
 11. Applicant's Email ID : ajay.khatri@igl.co.in dt-18/06/2021

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	As Per Directives	Provided at Site	Remarks MR/NMR
01	Access to building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 m N/A N/A	30 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	N/A	N/A	N/A
	b. Width of Staircases	N/A	N/A	N/A
03	Compartmentation.	Required	Provided	MR
04	Smoke Management System.	Required	Provided	MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> DCP type 10 Kg. DCP type 75 Kg. CO₂ type 4.5 Kg. IS Marking 	25 nos. 05 nos. 06 nos. ISI Marked	25 nos. 05 nos. 06 nos. ISI Marked	MR MR MR MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	N/A N/A	N/A N/A	N/A N/A
07	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Alternate source of power Hooter's location 	Gas Required Required Required	Provided Provided Provided Provided	MR MR MR MR
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A

N/11

13	Pumping Arrangements			
	Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the Pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
15	Exit Signage/ No Smoking Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A	N/A	N/A
17	Standby power supply.	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection systems			
	• CO ₂ DCP local application	Required	Provided	MR
	• Hand held explosive meter	02 nos.	Provided	MR

Keeping in view the compliance of the minimum standards on fire prevention and fire safety measures required under the rules, it is recommended to renew Fire Safety Certificate under rule 37 of Delhi Fire Service Rules, 2010.

Nagender Singh
 (Nagender Singh)
 ADO (Shahdara)

Dy. CFO (NDZ)

F.G. P.I.

Q. Kumar
 4/18/21

ADO (Shah)

Submitted please

AK
 10/8

Dy CFO (NDZ)

Q. Kumar
 10/18/21

M.S. Cell

