

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/WZ/2021/ 185

Dated: 16/8/2021

FIRE SAFETY CERTIFICATE

Certified that the M/s Haldiram Product Private Limited, Located at C-4, Ground Floor, Rajouri Garden New Delhi-110027 is running at Ground floor in a building comprised of Basement, Ground & three upper floor owned/Occupied by M/s. M/s Haldiram Product Private Limited have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire service Rules, 2010 and verified by the officer concerned of this department on 08-07-2021 in the presence of Sh. Satish Kaushik and found that the said building is fit for occupancy class " Assembly" Group D (Ground floor Only) with effect from 16/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/8/21 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

- Copy to: - 1. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi.
2. M/s Haldiram Product Private Limited located at C-4 Ground floor Rajouri Garden New Delhi 110027.
3. Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 10027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. This NOC is valid for **Ground floor** only.

INSPECTION REPORT

1. Name & address of the building : **M/s Haldi ram Product Private Limited** located at **C-4 Ground floor Rajouri Garden New Delhi 110027**
2. Type of Occupancy : **Assembly**
3. Type of Case : **New**
4. Details of previous NOC Letter no. : **Nil**
5. Fire Safety directives Letter No. : **N.A.**
6. Date of inspection : **08/07/2021**
7. Name of the Inspecting Officer : **Sarabjeet Singh ADO (MN)**
8. Name and designation of Officer
From the building side : **Sh. Satish Kaushik**
9. Year of Construction : **2010**
10. Applicant's email letter No : **Online application ID. No. 2021041913012 dated 21/04/2021**

The Restaurant is running at Ground Floor in a Building comprised of Basement + Ground + Three Upper Floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mts 05 mts NA	Provided Provided NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA (G.F.) NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA (G.F.) NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m X 1.5m	Provided (2m & 1.60m)	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	NA Required	NA Provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types 	4, ABC & CO ₂ ISI marked	Provided	MR

	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System:			
	• Basements	NA	Provided	--
	• Upper Floor	NA	Provided	--
	• Sprinkler above false ceiling	NA	Provided	--
11	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	1 No.	Provided	MR
	• Hose Box	1 No.	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	NA	Provided	NA
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	20,000 liters	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts:			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA

	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Fire Extinguishers provided near Electric Pannel.	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

153/ADO/MN
14/07/2021

DO (west)

[Signature]
15/7/2021

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)



~~DCFO (W2)~~

[Signature]
17/7/2021

[Signature]
19/7/2021

CAO

[Signature]
19/7

[Signature]

DO/W by also
visit this property the
what is on upper floor

Delhi

[Signature]
22/07