

C-28

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/2021/


614

Dated: 6/08/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Global Pratibha International School, Located at Ground & 1st Floor, Plot No-136-A, Yadav Bhawan Road, Bagdola Sector – 8 Dwarka, New Delhi – 110077 **in a building comprised of B+G+03 Upper Floors** owned/ occupied By Global Pratibha International School have complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 and verified by the officer concerned of this department on 04/08/2021 in the presence of Sh. Shubhash Gupta (HR Head) and found that the building is fit for occupancy class B “Educational building” (AT Ground and 1<sup>st</sup> Floor only) with effect from 16/8/21 for a period of three year.

Issued on 16/8/21 at New Delhi by.



(Atul Garg)  
Director

Delhi Fire Service.

Copy to:

1. Sh. Subhas Gupta ( HR Head) Global Pratibha International School, Located at Plot No-136-A, Yadav Bhawan Road, Bagdola Sector – 8 Dwarka, New Delhi – 110077
2. Directorate of Education Old Secretariat Delhi – 110054

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/1

INSPECTION REPORT

1. Name & address of the building: Global Pratibha International School, Located at Plot No-136-A, Yadav Bhawan Road, Bagdola Sector – 8 Dwarka, New Delhi – 110077.
2. Type of Occupancy : Educational (**At Ground +One Upper Floors Only in a building comprised of B+G+03 Upper Floors.**)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE Circular 3298 -3398 Dated 01/03/2011
6. Date of inspection : 04-08-2021
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Shubhash Gupta ( HR Head)
9. Year of Construction : 2009
10. Applicant's letter No. : Email dated 29/07/2021 & 03/08/2021

No. of Students=283 No. of class rooms=09 Plot area=1094 sqmtr Covered area=918 M <sup>2</sup> ( Both floors)
---

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular 3298-3398 Dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	06 mtrs	MR
	• Gate width	4.5mtrs	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 No's	02 No's	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	150 cms	Provided	M
	f. Door Size	100cm	01 mtr( Including Door Frame)	M
3.	Compartmentation			
	• Fire check door	NA	NA	
	• Sealing of electrical shafts	NA	NA	
	• Fire Rating of shaft door	NA	NA	
	• Water Curtain	NA	NA	
	• Fire Dampers	NA	NA	

4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 a/c per hour	NA	NA
		12 a/c per hour	Natural ventilation provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	04 nos. ABC & CO <sub>2</sub> ISI marked	04 Nos. Co2 & ABC Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA NA NA	Provided Provided Provided	NA NA NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	Provided NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA	NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA NA
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA NA NA NA 2500 ltr	NA NA NA NA 2500 ltr	NA NA NA NA MR

M13

15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers


..... Nil .....

Signature of the Inspecting Officer  
 Name *Ved Pr Singh*  
 Designation *ADP/2021*

*DO/SC*

*10/08/21*  
*10/08/2021*  
 Dy CFO (22)

*10/8*  
*10/8*  
*10/8*



*ADP/2021*

*CFO*

*10/8*

*10/8*