

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/NDZ/2021/ *Peta/ 386*

Dated: *12/08/2021*

FIRE SAFETY CERTIFICATE

Certified that the M/s Batra Car Care Centre (Petrol Pump cum Service Station) at Humayun Road, New Delhi, comprised of single story building owned / occupied by M/s Batra Car Care Centre, was earlier issued Fire Safety Certificate vide letter No. F6/DFS/MS/NNDZ/2018/1140 dated 18/05/2018. The premises was re-inspected by the officer concerned of Fire Service on 31.07.2021 in the presence of Sh. Puneet Bansal (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Hazardous (Group-J) with effect from 12/08/2021 for a period of 3 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *12/08/2021* **at New Delhi by.**



(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (S.Z.)

Copy to :-

1. Sh. Puneet Bansal (Manager), M/s Batra Car Care Centre (Petrol Pump cum Service Station), Humayun Road, New Delhi.

Conditions for the validity of Fire Safety Certificate:-

1. "No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
2. No trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical / electric spark should be allowed within the premises and its vicinity.
3. 04 no's of CO2 gas type ISI capacity of 4.5 kg, 02 no's of ABC stored pressure power type ISI capacity 05kg and 01 numbers of AFFF type ISI capacity 50 ltrs provided should be maintained in proper working order all the time.
4. The working employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
5. Overhead electric cable not passing across the licensed premises.
6. Work under procurement / installation mentioned in the undertaking shall be complied before the commencement of the plant. The same shall be get inspected from OISD under intimation to this department.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : **M/s Batra Car Care Centre (Petrol Pump cum Service Station) at Humayun Road, New Delhi.**
2. Type of Occupancy : **Group J Hazardous Building**
3. Type of Case : **Renewal (Single Story Building)**
4. Details of previous NOC : **F6/DFS/MS/NNDZ/2018/1140 dated 18/05/2018**
5. Fire Safety directives Letter No. : **NBC (Part-IV)**
6. Date of inspection : **31/07/2021**
7. Name of the Inspecting Officer : **A.D.O. (S.J.)**
8. Name and designation of Officer
from the building side : **Sh. Puneet Bansal (Manager)**
9. Year of construction : **2002**
10. Applicant's letter received through email **ID-batracc@yahoo.co.in** dated 16/07/2021

S. No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	NA	18 mtr	NA
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA		
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	1 foam of 50 kg, 1 DCP of 70 kg & 15 ABC of 4.5 kg	1 foam of 50 kg, 1 DCP of 70 kg & 15 ABC of 4.5 kg	MR
	• Types	ABC/DCP/Foam & CO ₂	Provided	MR
	• ISI marking	Required	Provided	MR

	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity (Use for washing the vehicles)	NA	6000 ltr	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA

15.	No Smoking Signage English & Hindi	Required	Provided English & Hindi	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Fire buckets filled with sand, no smoking boards & emergency no. were found displayed in Hindi & English. No loose electric wiring seen in premises.		

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/NNDZ/2018/1140 dated 18/05/2018 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Appraisal
02/08/2021

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (S.J.)

~~D.O. (S.J.)~~

~~DeFO (S.J.)~~

~~D.O. (S.J.)~~

ADD (S.J.)

Living
02/08/21 15:17

3/8

Living
04/08

F.T. is added for sign. pl.