

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2021/WZ/Motel/

403

Dated

18/08/2021

FIRE SAFETY CERTIFICATE

Certified that **Emerald Green Banquet Hall** located at **Tivoli Grand Resort Hotel, Kh. No.30-37, Village- JindPur, Main G.T.K. Road, Delhi-110036** comprised of **Ground Floor Only (Semi Pucca Steel Structure)** owned/ occupied by **M/s Tivoli Grand Resort Hotel** have complied with the fire prevention and fire safety arrangements in accordance with rule 33 of the Delhi Fire Service Rules,2010 and verified by officers concerned of Fire Service on 02/07/2021 in the presence of Sh. Jeeta Ram (Manager) and found that the building/Premises is fit for occupancy **Assembly(Banquet Hall)** with effect from18/08/2021 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, as mentioned below.

Issued on.....18/08/2021 at New Delhi.

(Ajul Garg)
Director

Delhi Fire Service

Copy to:-

1. Emerald Green Banquet Hall,located at The Tivoli Grand Hotel, Village- JindPur, G.T. Karnal Road, Delhi-36.
2. The Dy Health Officer, NDMC, Public Health Department, Narela Zone, Delhi-40.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : M/s Emerald Green Banquet Hall located at Tivoli Grand Resort Hotel, Khasra No. 30-37, Village Jindpur, Main G.T.K Road, Delhi-110036.
2. Type of Occupancy : Assembly
3. Building Comprised : Semi Pucca Steel structure (Ground Floor only)
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : F.6/DFS/MS/2019/5337 dated 05.09.2019
7. Date of inspection : 13/07/2021
8. Name of the Inspecting Officers : DO/NW and ADO/BW
9. Name and designation of officers from the building side : Sh. Jeeta Ram (Manager)
9. Year of Construction :
10. Applicant's letter No. : E Mail id dated 30/06/2021

Area of Banquet Hall- 3047.78 sqm

Minimum Standards on fire prevention and fire safety U/R 33		NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09m	09m	MR
	• Gate width	05m	05m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
		2 m × 8 nos.	2 m × 09 nos. & 1.20 m × 01 no.	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			

	<ul style="list-style-type: none"> Basements Ground floor Banquet Hall 	NA	NA	NA
		Required	Provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	11 nos	20 nos	MR
		ABC & Co2	ABC	MR
		Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04	06	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke / Heat	Provided	MR
		Ground floor	Provided	MR
		NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Ground Floor Banquet Hall Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		NA	Provided	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	150mm	Provided	MR
		04	06	MR
		Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm	900 lpm	MR
		40m	40m	MR


	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 ltr.	Provided <i>connected with motel</i>	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltr.	Provided at G.F & connected with motel building	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 33 of Delhi Fire Service Rules 2010.

Signature of Inspecting officer
Name: D.B Mukharjee
Designation: DO/NW

Signature of Inspecting Officer
Name: Rajeev Kumar Sinha
Designation: ADO/BW



DO/NW
[Signature]
14/7/2021

[Signature]
14/7/2021

[Signature]
13/7/21

[Signature]
14/7/2021