

C18

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/2021/ *School/SZ/618*

Dated: *16*/08/2021

FIRE SAFETY CERTIFICATE

Certified that the building S.D.M.C Co-Ed Primary School (ID 1757214) Located at Sector – 3, Phase –I, Dwarka, New Delhi-110075 comprised of Ground + One Upper Floor, owned/occupied by Delhi Govt. was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/2018/SZ/1259 Dated 29/05/2018. The premises was re inspected by the officer concerned of this department on 04/08/2021 in the presence of Smt. Raj Bala Sharma (Principal) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 and that the building is fit for occupancy class B “Educational building” with effect from *16/8/21* for a period of **three years**, subject to compliance of the condition printed as under.

Issued on *16/8/21* at New Delhi by.


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal S.D.M.C Co-Ed Primary School(ID 1757214) Located at Sector – 3, Phase –I, Dwarka, New Delhi-110075
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: S.D.M.C Co-Ed Primary School(ID 1757214) Located at Sector – 3, Phase –I, Dwarka, New Delhi-110075.
2. Type of Occupancy : Educational (Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2018/SZ/1259 Dated 29/05/2018
5. Fire Safety directives Letter No. : . Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 04/08/2021
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Smt. Raj Bala Sharma (Principal)
9. .Year of Construction : 1984
10. Applicant's letter No. : Email Dated - 13/07/2021

No. of Students=635
No. of class rooms=20
Plot area=5996 sqmtr
Covered area=693 sqmtr

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/3	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5mtrs	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	150 cm/additional staircase of 75 cm if less than 150 cm	1.05 mtr & 1.03 mtr	MR(Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	01 mtr	01 mtr	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilation provided	MR

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric meter	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no F.6/DFS/MS/School/2018/SZ/1259 Dated 29/05/2018 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Udai Vir Singh
 Designation ADCP/DWK

DOSW

05/06/2021

By ch (f2) F.F. plst

ADCP/DWK

Sir PT letter is put up for sign blr

to 4/18