

C-33

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2021/ 620

Dated: 18/08/2021

FIRE SAFETY CERTIFICATE

Certified that the Akshay Public School, Located at Kh, No. 186/2, Sector-16B, Dwarka, Kakrola, New Delhi-110043. comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F.6/DFS/MS/School/2017/SZ/1274 Dated 24/08/2017 (Issued to G + 01 UF only). The premises was re inspected by the officers concerned of this department on 14/07/2021 in the presence of Smt. Kanta Rani (Principal) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with circular no. 3298-3398 Dated 01/03/2011 issued by the Director of Education rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Educational" with effect from 18/8/21 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...18/8/21... at New Delhi by.


Atul Gang
Director

Delhi Fire Service.

Copy to:

1. The Principal, Akshay Public School, Kh, No. 186/2, Sector-16B, Dwarka, Kakrola, New Delhi-110043.
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/18

INSPECTION REPORT

1. Name & address of the building: Akshay Public School, Located at, Kh, No. 186/2, Sector-16B, Dwarka, Kakrola, New Delhi-110043.
2. Type of Occupancy : Educational (Ground + 02 Upper Floor)
3. Type of Case : NEW
4. Details of previous NOC : F.6/DFS/MS/School/2017/SZ/1274 Dated 24/08/2017 (FSC Issued to Ground + 01 Upper floor)
5. Fire Safety directives Letter No. : circular no. 3298-3398 Dated 01/03/2011
6. Date of inspection : 14/07/2021
7. Name of the Inspecting Officer : Udai Vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Smt. Kanta Rani (Principal)
9. Year of Construction : 2014 (GF &FF) 2016-17 (SSF)
10. Applicant's letter No. : Email Dated-30/06/2021

S No	Minimum standards on fire prevention and fire safety U/R 33	circular no. 3298-3398 Dated 01/03/2011 As per N/10	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5mtrs NA	07 mtrs Directly accessible from road NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	02 No's NA	02 No's NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	150 cms NA	2x 150 cms NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA	NA NA	NA NA
	d. No of continuous staircase to terrace			
	<ul style="list-style-type: none"> • No of continuous staircase to terrace 	NA	NA	NA
	e. Width Of Corridor			
	<ul style="list-style-type: none"> • Width Of Corridor 	150 cms	195cm	MR
	f. Door Size			
	<ul style="list-style-type: none"> • Door Size 	100cm	100cm (double door)	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA

21/20

14.	Captive water Storage for fire fighting:		
	• Under ground tank capacity	NA	NA
	➤ Draw off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	10,000Ltr	Provided
15	Exit Signage	Required	Provided
16.	Provision of Lifts		
	➤ Pressurization of Lift Shaft	NA	NA
	➤ Pressurization of lift lobby	NA	NA
	➤ Communication in lift Car	NA	NA
	➤ Fireman's Grounding Switch	NA	NA
	➤ Lift Signage	NA	NA
17.	Standby power supply	NA	NA
18.	Refuge Area		
	➤ Total area	NA	NA
	➤ Location	NA	NA
19.	Fire control room		
	➤ Detector system panel	NA	NA
	➤ Flow Switch Panel	NA	NA
	➤ PA System Panel	NA	NA
	➤ Battery backup	NA	NA
	➤ Building Floor Plans	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter : F.6/DFS/MS/School/2017/SZ/1274 Dated 24/08/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ASO/DWTA

Dolsca - It is a case of addition of one upper floor and now the composition of bldg. is 4+2 u.f.
 • Educational bldg. having 4+2 u.f. is covered in rule - 27 therefore school must qualify the fire protection requirements as contained in UBBL - 2016 & NBC - 2016.
 • File may be sent to ASO (DWA) for re-examination and necessary corrections in inspection Report & f.s.c. pl