

c-17

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[See sub-rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2021/SZ/ 615

Dated: 16/8 /2021

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Sarvodaya Bal Vidyalaya located at Bijwasan-Bharthal, New Delhi-110077 (ID-1821032) comprised of Ground + one upper floor (Three Blocks) & Ground floor (One Block) owned / Occupied by Director of Education have been issued Fire Safety Certificate vide letter No. F.6/DFS/MS/School/2018/SZ/1587 dated 06/07/2018. The premises was re-inspected by the officer concerned of this department on 03.08.2021 in the presence of Sh. V.P. Meena (HOS) and all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with circular No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 16/8 /2021 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010

Issued on 16/8 /2021 at New Delhi by



(SUNIL CHAUDHARY)

DY. CHIEF FIRE OFFICER (SZ)

Copy to: -

1. The HOS, Govt. Sarvodaya Bal Vidyalaya, Bijwasan - Bharthal, New Delhi-110077.
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in).



## INSPECTION REPORT

1.	Name & address of the building	Govt. Sarvodaya Bal Vidyalaya, Bijwasan-Bharthal, New Delhi-110077 (ID-1821032)		
2.	Type of Occupancy	Educational		
3.	Building Comprised of	G + 1 (3 Blocks) & Ground Floor (1 Block)		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/School/2018/SZ/1587 dated 06/07/2018		
6.	Fire Safety directives Letter No	DOE Cir. Dated 01/03/2011		
7.	Date of Inspection	03.08.2021		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and Designation of Officer from the building side	Sh. V.P. Meena (HOS)		
10.	Year of Construction	1952		
11.	Applicant's letter No.	Bij/2021/476 dated 22/06/2021		
S. No	Minimum standards on fire prevention and fire safety U/R 33	DOE Cir. Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Required	6m	MR
	• Gate width	Required	5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 in each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 m / 0.75m	A Blk-1.47m & 1.44m, B Blk-1.44m x 2 & C Blk-1.44m & 1.38m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	14 Nos	17 Nos.	MR
	• Types	ABC / CO <sub>2</sub>	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA



21/9

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
9.	Public Address System			
		NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage			
		Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply			
		NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA



19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2018/SZ/1587 dated 06/07/2018, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

*[Signature]*  
06/08/2021

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation: ADO (SJ)

DO (SD) *[Signature]*  
09/08/21

Dfsc(SJ) *[Signature]* F.T. please.

ADO(S.D.) *[Signature]*  
11/08/21

ADO(SJ) F.T. is added for sign. pl. *[Signature]*  
12/08/2021

Dy. CFO (SZ) *[Signature]*  
M.S. *[Signature]*