

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2021/WZ/Cos/ 402

Dated: 18/08/2021

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Aakarsh International (Nail Polish), I-94, Sec-3, Bawana, Industrial Area, Bawana Delhi-110039 located at Ground Floor Only in a building comprised of Basement+Ground+Two upper floors owned/occupied by M/s Aakarsh International was issued fire safety certificate vide Letter No. F6/DFS/MS/2018/WZ/1559 dated 04/07/2018 have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 06/08/2021 in the presence of Sh. Manoj Jain and that the building premise is fit for occupancy under "Class Industrial Building G-2(ii)" for Ground Floor only with effect from .....18/08/2021 for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on .....18/08/2021 at New Delhi

(Dharampal Bhardwaj)  
Dy.Chief Fire Officer  
WEST ZONE

**Conditions for the validity of Fire Safety Certificate:**

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Copy to :-

1. M/s Aakarsh International, I-94, Sector-3,Bawana Industrial Area, Delhi-39.
2. Dy. Drug controller /licensing authority Govt. of NCT. Of Delhi, Drug Controller Department, F-17, Karkardooma, Delhi-110032.

**INSPECTION REPORT**

1. Name & address of the building: M/s Aakarsh International ,I-94, Sector-3 , DSIIDC  
Bawana Industrial Area, Delhi-39
2. Type of Occupancy :Industrial G-2(ii)
3. Building Comprised : **B+Gr.+2 upper floors, (FSC for Ground Floor Only)**
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/2018/WZ/1559 Dated-04/07/2018
6. Fire Safety directives letter No : NBC Part IV
7. Date of inspection : 06.08.2021
8. Name of the Inspecting Officers : ADO, R.K Sinha
9. Name and designation of officers  
from the building side :Sh. Manoj Jain
9. Year of Construction :2012-13
10. Applicant's letter No. :E Mail ID Dated-04/08/2021

| S. No | Minimum Standards on fire prevention and fire safety U/R 33                       | NBC Requirement | Provided at site    | Remarks MR/NMR |
|-------|---|-----------------|---------------------|----------------|
| 1     | <b>Access to building</b>   |                 |                     |                |
|       | • Road width  | 06 m            | Directly Accessible | MR             |
|       | • Gate width  | 4.5 m           | 4.5 m               | MR             |
|       | • Width of internal road  | NA              | NA                  | NA             |
| 2     | <b>Number, Width, Type &amp; Arrangement of Exits (FSC for Ground Floor only)</b> |                 |                     |                |
|       | a. Number of staircases   |                 |                     |                |
|       | • Upper Floors  | NA              | 01                  | NA             |
|       | • Basements   | NA              | 01                  | NA             |
|       | b. Width of staircases  |                 |                     |                |
|       | • Upper Floors  | —               | 1.20 m              | —              |
|       | • Basements   | —               | 1.20 m              | —              |
|       | c. Protection of exits  |                 |                     |                |
|       | • Fire check door   | NA              | NA                  | NA             |
|       | • Pressurization  | NA              | NA                  | NA             |
|       | d. No. of continuous staircases to terrace  | NA              | 01                  | NA             |

*M*

|    |  |                |                    |     |
|----|--|----------------|--------------------|-----|
|    | e. Width of Corridor                                 | NA             | NA                 | NA  |
|    | f. Door Size   | 1.00 m × 2     | Provided           | MR  |
| 3  | <b>Compartmentation.</b>                             |                |                    |     |
|    | • Fire check door                                    | NA             | NA                 | NA  |
|    | • Sealing of electrical shafts                       | NA             | NA                 | NA  |
|    | • Fire Rating of shaft door                          | NA             | NA                 | NA  |
|    | • Water Curtain                                      | NA             | NA                 | NA  |
|    | • Fire Dampers                                       | N/A            | N/A                | N/A |
| 4  | <b>Smoke Management System.</b>                      |                |                    |     |
|    | • Basements  | 30a/c per hour | NA                 | NA  |
|    | • Upper floors                                       | 12a/c per hour | Natural Ventilated | MR  |
| 5  | <b>Fire Extinguishers</b>                            |                |                    |     |
|    | • Total numbers                                      | 09 nos         | 10 nos             | MR  |
|    | • Types  | ABC            | ABC                | MR  |
|    | • IS marking   | Required       | Yes                | MR  |
| 6  | <b>First-Aid Hose Reels.</b>                         |                |                    |     |
|    | • Total numbers on each floor                        | 01             | Provided           | MR  |
|    | • Length of hose reel hose                           | 30m            | Provided           | MR  |
|    | • Nozzle diameter                                    | 5mm            | Provided           | MR  |
| 7  | <b>Automatic fire detection and alarming system.</b> |                |                    |     |
|    | • Type of detectors                                  | NA             | NA                 | NA  |
|    | • Location of Main Panel                             | NA             | NA                 | NA  |
|    | • Location of Repeater Panel                         | NA             | NA                 | NA  |
|    | • Alternate source of power                          | NA             | NA                 | NA  |
|    | • Hooters' Location                                  | NA             | NA                 | NA  |
| 8  | <b>MOEFA</b>   | NA             | NA                 | NA  |
| 9  | <b>Public Address System.</b>                        | NA             | NA                 | NA  |
| 10 | <b>Automatic Sprinkler System.</b>                   |                |                    |     |
|    | • Basement   | —              | Provided           | —   |

*Handwritten signature*

2/19

|    |  |             |            |    |
|----|--|-------------|------------|----|
|    | <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul> | Required    | Provided   | MR |
|    |  | —           | —          | —  |
| 11 | <b>Internal Hydrants</b>   |             |            |    |
|    | • Size of riser/down-comer   | NA          | NA         | NA |
|    | • Number of hydrants per floor   | NA          | NA         | NA |
|    | • Hose Box   | NA          | NA         | NA |
| 12 | <b>Yard Hydrants.</b>  |             |            |    |
|    | • Total number of hydrants   | NA          | NA         | NA |
|    | • Hose Box   | NA          | NA         | NA |
| 13 | <b>Pumping Arrangements.</b>   |             |            |    |
|    | ➤ Ground Level   |             |            |    |
|    | ➤ Discharge of main Pump   | NA          | NA         | NA |
|    | ➤ Head of Main pump  | NA          | NA         | NA |
|    | ➤ Number of main pumps   | NA          | NA         | NA |
|    | ➤ Jockey Pump out put  | NA          | NA         | NA |
|    | ➤ Jockey pump head   | NA          | NA         | NA |
|    | ➤ Standby Pump out put   | NA          | NA         | NA |
|    | ➤ Standby Pump Head  | NA          | NA         | NA |
|    | ➤ Auto Starting/ Manual stopping   | NA          | NA         | NA |
|    | ➤ Pump House Access  | NA          | NA         | NA |
|    | • Terrace level  |             |            |    |
|    | ➤ Discharge of pump  | 450 LPM     | Provided   | MR |
|    | ➤ Head of the pump   | 40 m        | Provided   | MR |
|    | ➤ Power Supply   | Required    | Provided   | MR |
|    | ➤ Auto Starting of pump  | Required    | Provided   | MR |
| 14 | <b>Captive Water Storage for fire fighting.</b>  |             |            |    |
|    | • Underground tank capacity  | NA          | NA         | NA |
|    | ➤ Draw-off connection  | NA          | NA         | NA |
|    | ➤ Fire service inlet   | NA          | NA         | NA |
|    | ➤ Access to tank   | NA          | NA         | NA |
|    | • Overhead Tank capacity   | 10,000 ltrs | 10,000ltrs | MR |

*Dr*

| 15 | Exit Signage.  | Required | Provided | MR |
|----|--|----------|----------|----|
| 16 | <b>Provision of Lifts.</b>   |          |          |    |
|    | • Pressurization of Lift Shaft   | NA       | NA       | NA |
|    | • Pressurization of Lift lobby   | NA       | NA       | NA |
|    | • Communication In lift Car  | NA       | NA       | NA |
|    | • Fireman's Grounding Switch   | NA       | NA       | NA |
|    | • Lift Signage   | NA       | NA       | NA |
| 17 | <b>Standby power supply</b>  | NA       | Provided | NA |
| 18 | <b>Refuge Area.</b>  |          |          |    |
|    | ➤ Total Area   | NA       | NA       | NA |
|    | ➤ Location   | NA       | NA       | NA |
| 19 | <b>Fire Control Room</b>   |          |          |    |
|    | • Detector System Panel  | NA       | NA       | NA |
|    | • Flow Switch Panel  | NA       | NA       | NA |
|    | • PA System Panel  | NA       | NA       | NA |
|    | • Batter backup  | NA       | NA       | NA |
|    | • Building Floor Plans   | NA       | NA       | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA       | NA       | NA |

The fire protection systems provided in the building were tested/ checked randomly and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standard on fire prevention and fire safety required under the rules, the FSC issued vide letter no. F6/DFS/MS/2018/WZ/1559 dated 04/07/2018 is recommended for renewal of Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010

*(Signature)*  
ADO(BW)  
11/8/21

Signature of the Inspecting Officer  
Name: - Rajeev Kumar Sinha  
Designation-ADO/BW

*(Signature)*  
DO (WZ)

*(Signature)*  
12/08/2021

*(Signature)*  
DO (WZ)

*(Signature)*  
10/8/2021

*(Signature)*  
F.T letter of Putup for sign please

*(Signature)*  
ADO(BW)  
17/8/21