

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/GH/2021/NDZ/ 389

Dated 13/08/2021

FIRE SAFETY CERTIFICATE

Certified that the M/S S.K. Kumar Banquet Hall located at Plot No. 12 Gazipur Automobile Center Near EDM Mall, Delhi, running only on ground and first floor owned / occupied by M/S S.K. Kumar Party Hall . The building comprised of basement, ground plus two upper floors. The building was inspected by the officer concerned of this department in the presence of Mr. Sharma (Manager) and others of the premise and found that the Assembly building have complied with the Fire prevention and Fire safety requirements in accordance with the rules . The Fire Safety Certificate under rule 35 unless renewed under rule 36 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group "D" "Assembly Building" for ground plus one upper floor with effect from 13/08/2021 for a period of three years, subject to conditions printed overleaf.

Issued on.....13/08/2021.....at New Delhi by


(Atul Garg)
Director

Copy to:-

Deputy Health Officer,
Shadhra South zone,
Karkardooma,
East Delhi Municipal Corporation Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : M/s S.K.KUMAR Banquet Hall,
Plot No.12, Gazipur, Automobile Centre,
Near EDM Mall, Delhi - 110092.
2. Building is comprised of : Basement, Ground plus two upper Floors
(Banquet hall is running at G+1 only)
3. Type of Occupancy : **Assembly Building**
4. Type of Case : New,
5. Details of Previous NOC : F.6/MS/DFS/2001/1309 dated 5/7/2001
for Industrial building
6. Fire Safety directive letter No : F/6/DFS/MS/2019/BP/3897 dated 1/7/19,
7. Date of Inspection : 19/03/2021
8. Name of the Inspecting officers : DO Francis Brown
9. Name and designation of officer
from the building side : Mr. Sharma (Manager)
10. Year of construction : 1995,
- 11 Applicant's letter No : on - line 20210310111155 dated 18/3/21

S.No	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NM R
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09 m N/A N/A	15 m 7.4m N/A	MR MR N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	03 N'os 03 N'os	04 N'os 03 N'os	MR MR
	b. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	02 mtr 02 mtr	02mtr x 3 nos. 1.5mtr x 1 nos. 02mtr x 3 nos	MR MR
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of Continuous Staircases to Terrace	02 nos.	03 nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr	02 mtr	MR
	g. Number of Doors	02 nos.	02 nos.	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	Required Required Required N/A Required	Provided Provided Provided N/A Provided	MR MR MR N/A MR
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	30a/c per hrs 12 a/cper hrs	provided provided	MR MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	12 nos. ABC /CO ₂ ISI marked	16 Nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	03 no.	03 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	NA	Smoke	NA
	• Location of main panel	NA	provided	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	NA	NA	NA
08	MOEFA	Required	Provided	MR
09	Public Address System.	NA	Provided	NA
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	NA
	• upper floor	NA	Provided	NA
	• sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	02 no.	02 no.	MR
	• Hose box	02 no.	02 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose box	NA	NA	NA
13	Pumping Arrangements.			
NA	• Ground Level			
N	• Discharge of main pump	2280LPM	2280LPM	MR
A				
NA	• Head of main pump	70 mtr	70 mtr	MR
N	• Number of main pumps	01	01	MR
A	• Jockey pump out put	180lpm	180lpm	MR
NA	• Jockey pump head	70 mtr	70 mtr	MR
NA	• Standby pump out put	2280LPM	2280LPM	MR
	• Standby pump head	70 mtr	70 mtr	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	900LPM	900LPM	MR
	• Head of the pump	70 mtr	70 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000ltrs	2,00,000ltrs	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000ltrs	30,000ltrs	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch			
	• Lift Signage			
17	Standby power supply	Required	provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	HT LT Panel	Provided	MR

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial deemed compliance of the minimum standards on fire prevention and fire safety required under the NBC Part IV, it is recommended to issue Fire Safety Certificate.

[Handwritten Signature]
22/3

Signature of the Inspecting Officer
Name: Francis Brown
Designation: DO (East)

DCFO(NDZ)
[Handwritten Signature]
24/3/21

CFO(HD) - D/OB

Director
[Handwritten Signature]

[Handwritten Note]
I have not
my name is not
by me cos
g

[Handwritten Signature]

[Handwritten Signature]