

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2021/628

Dated:- 23 /08/2021

FIRE SAFETY CERTIFICATE

Certified that the **Salwan Public School** located at **Mayur Vihar Ph-III, Delhi-96** comprised of **Ground + 04 Upper floors**, owned/occupied by **Salwan Public School**, was granted FSC by this department vide letter No. **F6/DFS/MS/2018/NDZ/302** dated **26/02/2018**. The premises was re-inspected by the officer concerned of this department on 03/08/2021 in the presence of the Mr. A.K Tyagi & Mr. Manoj Verma (Estate Officer) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class **“B” ‘Educational Building’ Ground + 04 Upper floors only** with effect from 23/08/2021 for a period of **three** years, subject to conditions, printed below.

Issued on 23/08/2021 at New Delhi by.


(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education,
D-Block, Anand Vihar, Delhi-91.
2. The Principal,
Salwan Public School, Mayur Vihar Ph-III, Delhi-96.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.

2/19
INSPECTION REPORT

1. Name & address of the building Salwan Public School, Mayur Vihar Ph-III, Delhi-96
2. Type of occupancy:- Educational Group-B
Ground + 04 Upper floors
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/2018/NDZ/302 dated 26/02/2018
5. Fire safety directives No.- F6/FDS/MS/2005/478 dated 04.03.2005
6. Date of inspection:- 03/08/21
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/LN)
8. Name & designation of officer
From the building side:- Mr. A.K Tyagi & Mr. Manoj Verma (Estate Officer)
9. Year of construction:- 2004
10. Applicant's letter No:- letter no.SPS/MV/20-21/0186 dated 21/06/2021

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Old Circular	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	15 mtr.	MR
	2) Gate width	4.5 m	4.5 m	MR
	3) Width of internal road	6m	6 m	MR
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos.	02 nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 m	1.5 m, 1.7 m	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01 nos.	02 nos.	MR
	E. Width of corridor	1.5 mtr.	2 mtr.	MR
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	20 Nos.	20 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 nos.	02 nos.	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR

N/20

7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	MR
9.	Public Address System	N/A	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	100 mm	MR
	2) Number of hydrants per floor	N/A	2 no.	MR
	3) Hose box	N/A	2 no.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	60,000 ltr.	MR
	a) Draw-off connection	N/A	Provided	MR
	b) Fire service inlet	N/A	Provided	MR
	c) Access to tank	N/A	Provided	MR
	d) Over head tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A

17.	Stand by Power Supply	N/A	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/School/2021/130 dated 04/03/2021 have been rectified.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/2018/NDZ/302 dated 26/02/2018, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma
 Name :- M.K. Sharma
 Designation :- ADO (LN)

Dy.CFO/NDZ

K. Kumar
 12/8/21

CFO (N.O.)

[Signature]
 12/8

[Signature]
 18/8/2021

[Signature]

